

RECEIVED

DEC 03 2002

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only		
Inspected by _____		
Twp _____	Rge _____	Sec _____
1/4	1/4	1/4
Lat: : : _____	Long: : : _____	

IDWR/North

1. WELL TAG NO. D0022977

DRILLING PERMIT N 788832

Other IDWR No _____

2. OWNER:

Name Sylvia Zehnter

Address P O Box 144

City Frazer Park State CA Zip 93225

3. LOCATION OF WELL by legal description:

N
Twp 54N North ☒ or South ☐
Rge 04W East ☐ or West ☒
Sec 35 1/4 SW 1/4 NE 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot _____ County Bonner
Lat _____ Long _____

Address of Well Site: (see next line)

Clagstone _____ City _____
Lot _____ Blk _____ Sub. Name (see next line) _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
BENTONITE	0	18	8 SACKS	DRY POUR

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	367	0.025	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____
☒ Screens? Screen Type STAINLESS STEEL

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
365	375	20		5	STAINLE	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

298 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 298 ft. Describe access port or

control devices: STEEL CAP WELDED

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
20	100%	370	3 HOURS

Water Temp. _____ COLD Bottom hole temp. _____ COLD

Water Quality test or comments: (below) Depth first Water Encountered 298

CLEAR, COLD, NO SMELL

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	1	Topsoil	☐	☒
8	1	126	Sand & gravel	☐	☒
8	126	272	Clay - Brown	☐	☒
8	272	298	Sand & gravel - Fine	☐	☒
8	298	320	Sand - Brown - Course	☒	☐
8	320	342	Sand & gravel - Fine	☒	☐
8	342	380	Sand & gravel - Fine	☒	☐

Completed Depth 375 (Measurable)

Date: Started 11/2/02 Completed 11/7/02

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414

Firm Official Tim M. Valley p.m.s. Date 11/8/02

Supervisor or Operator Jason C. Beckham Date 11/8/02

54N 4W 35