

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

RECEIVED

77146

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	Long	:

1. WELL TAG NO. D 10876
DRILLING PERMIT NO. NOV 19 1999
Other IDWR No. 96-99-N-271

2. OWNER: AI and Darryl KYLE IDWR/North
Name E. 9105 Bunco Rd.
Address Arhol State Id Zip 83801
City

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N W E S	Twp. <u>53</u>	North ☒ or South ☐
	Rge. <u>3</u>	East ☐ or West ☒
	Sec. <u>35</u>	NE 1/4 SW 1/4 NE 1/4
	Gov't Lot	County <u>ROBERTSON</u>
Lat		Long
Address of Well Site <u>9105 E Bunco</u>		
City <u>Arhol</u>		

(Give at least name of road - Distance to Road or Landmark)

Lt. _____ Bk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	20	5	Overbored

Was drive shoe used? ☒ N Shoe Depth(s) 47'
Was drive shoe seal tested? ☒ N How? AIR PRESSURE

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
4"	1	47	250	STEEL	☒	☐	☒	☐
4"	-10	275	70	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations Method SAW CUT
Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
275	190	1/8x6	40	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

70 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min	Drawdown	Pumping Level	Time
60			4 Hours

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	8	Soil and GRAVEL		
10	8	39	Loose GRAVEL		
10	39	45	Decomposed GRANITE		
10	45	47	Weathered GRANITE		
6	47	70	GRANITE		
6	70	72	Fractured GRANITE		
6	72	192	GRANITE		
6	192	193	Fractured GRANITE		
6	193	227	GRANITE		
6	227	252	Fractured GRANITE		
6	252	295	With Fractured Quartz	35	
6	295	297	GRANITE		
6	297	275	Fractured GRANITE	25	
6	275	275	GRANITE		

Completed Depth 275 (Measurable)
Date: Started 10-25-99 Completed 10-27-99

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Hester Well Drilling Firm No. 528

Firm Official [Signature] Date 11-16-99

and Driller or Operator [Signature] Date 11-2-99

(Sign once if Firm Official & Operator)

53 N 3 W 35 FORWARD WHITE COPY TO WATER RESOURCES

CONTINUED

APR 15 2009