

Form 23-1
RECEIVED
JAN 21 1999

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

076823

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 1/4 1/4
Lat: : : Long: : :

1. WELL IDENTIFICATION: D0005716

DRILLING PERMIT NO. 96-99-N-2

Other IDWR No. _____

2. OWNER:

Name Dan Boss

Address 1555 E. Brunner

City Athol State ID Zip 83814

3. LOCATION OF WELL by legal description:

N
W E
S
Twp 54N North ☒ or South ☐
Rge 04W East ☐ or West ☒
Sec 25 1/4 SE 1/4 SE 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot _____ County Kootenai Bonner
Lat _____ Long _____

Address of Well Site: (see next line)

same City _____

Lot _____ Blk _____ Sub. Name (see next line) _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	14 sacks	pour in

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 438 - Ring Bit

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrded
6"	2	-438	0.025	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____
☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

390 ft. below ground. Artesian pressure _____ lb.
Depth flow encountered 390 ft. Describe access port or
control devices: Steel cap welded

11. WELL TESTS

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
40+	100%	535	1 hr.

Water Temp. _____ cold Bottom hole temp. _____ cold
Water Quality test or comments: (below) _____ Depth first Water Encountered 390
clear, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8"	0	2	Topsoli	☐	☒
8"	2	18	Sand & gravel & clay - 3/4 minus	☐	☒
6"	18	220	Sand & gravel & clay - brown - 3/4 minus	☐	☒
6"	220	390	Sand & gravel & clay - gray - 3/4 minus	☐	☒
6"	390	438	Sand & gravel - 3/4 minus	☒	☐

Completed Depth 438 (Measurable)
Date: Started 1/4/99 Completed 1/7/99

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc Firm No 414

Firm Official [Signature] Date 1/7/99

Supervisor or Operator Jason C. Beckham Date 1/7/99

FORWARD WHITE COPY TO WATER RESOURCES

117

54N 4W 25