

WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat:	:	Long:

1. WELL TAG NO. D0028291

Drilling Permit No: 798721
Other IDWR No. _____

2. OWNER

Name PLECHNER, A.J. D.V.M.

Well Number: _____

556

Address 1736 SEPLUED BLVD.

City LOS ANGELES State CA Zip 90025

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N	
W	E
S	
X	

Twp. 50 ☒ North or ☐ South
Rge. 2 ☐ East or ☒ West
Sec. 18 1/4 SE 1/4 SE 1/4
Gov't Lot _____ County KOOTENAI
Lat. : : Long. : :
Address of Well Site BLUE CRK RD.
PAST NEWELL RD. City COEUR D' ALE
(Give at least name of road + Distance to Road or Landmark)
Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
DRY GRANULE				
BENTONITE	0	18	4 BAGS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 78

Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner Welded	Threaded
6	+2	78	.250	STEEL	☒	☐	☒
4	-62	182	.160	PVC	☐	☒	☒

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method SKIL SAW

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
162	182	1/8 X 6	50	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

40 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 175 ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10 - 15			1 HR

Water Temp. COLD Bottom Hole Temp COLD

Water Quality test or comments: CLOUDY

Depth first Water encountered 73

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water
8	0	2	Top Soil	☐ Y ☐ N
8	2	26	Tan Clay	☐ Y ☐ N
8	26	73	Tan Clay w/ Gravels	☐ Y ☐ N
8	73	76	Tan Clay w/ Gravels	☒ Y ☐ N
6	76	118	Gray Shale	☐ Y ☐ N
6	118	127	Gray Shale	☒ Y ☐ N
6	127	141	Gray Shale	☐ Y ☐ N
6	141	149	Grayish Brown Shale	☒ Y ☐ N
6	149	170	Gray Shale	☐ Y ☐ N
6	170	175	Gray Shale	☒ Y ☐ N
6	175	182	Gray Shale	☐ Y ☐ N

RECEIVED

MAY - 6 2003

IDWR North

Completed Depth 182 (Measurable)

Date: Started 4/29/03 Completed 4/30/03

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Todd Morgan Date 5-1-03

and Supervisor or Operator Todd Morgan Date 5-1-03

(Sign Once if Firm Official and Operator)

(Todd Morgan)

50N 2W 18