

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat:	:	Long:

1. WELL TAG NO. **D0013928**

RECEIVED

11. WELL TESTS:

DRILLING PERMIT N

Other IDWR No

767580

DEC - 7 2000

2. OWNER:

Name **Don Hollen**

Address P O Box 1193

City Capitola

State CA

Zip 95010

3. LOCATION OF WELL by legal description:

N	Twp	53N	North	✓	or	South
	Rge	03W	East		or	West
	Sec	06	1/4	NE	1/4	SW
			10 Ac	40 Ac	160 Ac	
	Gov't Lot		County	Kootenai		
	Lat		Long			
	Address of Well Site: (see next line)					

Clagstone

City

Lot

Blk

Sub. Name (see next line)

4. USE:

✓ Domestic Municipal Monitor Irrigation
Thermal Injection Other

5. TYPE OF WORK check all that apply (Replacement etc.)

✓ New Well Modify Abandonment Other

6. DRILL METHOD

✓ Air Rotary Cable Mud Rotary Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	19	10 sacks	Pour in

Drive Shoe Used? Y ✓ N Shoe Depth(s)

Drive Shoe Seal Tested? Y ✓ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	516	0.250	Steel	✓		✓	

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

Perforations? Method

Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

465 ft. below ground. Artesian pressure lb.

Depth flow encountered 465 ft. Describe access port or

control devices: Steel cap welded

Pump Bailer ✓ Air Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
10+	100%	515	2 hrs

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 465

clear, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	2	Topsoil		✓
8	2	19	Sand & gravel - 3/4 minus		✓
6	19	180	Sand & gravel - 3/4 minus		✓
6	180	250	Sand & gravel - 3/8 Minus		✓
6	250	380	Sand & gravel - 3/4 minus		✓
6	380	385	Boulder		✓
6	385	392	Sand & gravel - 3/4 minus		✓
6	392	400	Boulder		✓
6	400	465	Sand & gravel - 3/4 minus		✓
6	465	516	Sand & gravel - 3/4 minus	✓	

Completed Depth 516 (Measurable)

Date: Started 11/29/00 Completed 12/4/00

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc Firm No 414

Firm Official and Date 12/6/00

Supervisor or Operator Jason C. Beckham Date 12/6/00

FORWARD WHITE COPY TO WATER RESOURCES

358

53N 3W 6