

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat			Long

1. WELL TAG NO. D0045147

Drilling Permit No: 841264
Other IDWR No.

2. OWNER


Name Riley Ritter Construction Co. Ltd Well Number: 1204

Address PO Box 1570

City Post Falls State ID Zip 83877

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 54 ☒ North or ☐ South
Rge. 03 ☐ East or ☒ West

Sec. 33 NE 1/4 SW 1/4 1/4

Gov't Lot County KOOTENAI

Lat : : Long: : :

Address of Well Site Dancing Lights Lane
City Athol

(Give at least name of road + Distance to Road or Landmark)

Lt. : : Blk. : : Sub. Name : : :

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	500lbs	Temp Casing

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) RB

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	2	445	.250	Steel	☒	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☐ Perforations Method

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

320 ft. below ground Artesian pressure lb.

Depth flow encountere ft. Describe access port or control devices:

54N 3W 33

11. WELL TESTS:

☐ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>30</u>			<u>1.5</u>

Water Temp. cold Bottom Hole Temp cold

Water Quality test or comments: clear

Depth first Water encountered 370

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	Y	N
10	0	18	Sand, Gravel, Boulders	☐	☒	
8	18	120	Sand, Gravel 3/4 minus	☐	☒	
8	120	160	Sand, Gravel, Boulders	☐	☒	
8	160	260	Sand, Gravel 3/4 minus	☐	☒	
8	260	370	Cemented Sand, Gravel	☐	☒	
8	370	390	Fine sands approx 30gpm	☒	☐	
8	390	420	Large gravels 3/4+, coarse sands, large b	☐	☒	

RECEIVED

AUG 8 2006

IDWR/North

RECEIVED

SEP 20 2006

IDWR/North

Completed Depth 420 (Measurable)
Date: Started 8/8/2006 Completed 8/15/2006

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official Mark R. Hylleberg Date 8-17-06

and

Supervisor or Operator Mike Halterman Date 08/18/06

(Sign Once if Firm Official and Operator)

MAR 08 2017