

RECEIVED

Form 238-7
11/92

JAN 06 2003

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

IDWR/North

1. WELL TAG NO. D0022979

DRILLING PERMIT N

789205

Other IDWR No

2. OWNER:

Name Michael Van Skaik

Address 17706 35th Ave S E

City Bothell

State WA

Zip 98012

3. LOCATION OF WELL by legal description:

N		Twp	53N	North	☒ or	South	☐
Rge		05W	East	☐ or	West	☒	
Sec		14	1/4	NE	1/4	NE	1/4
Gov't Lot			10 Ac	40 Ac	160 Ac		
County		Kootenai					
Lat							
Long							

Address of Well Site: (see next line)

Hwy 41 to Main in Spirit Lake 3.5 m on Spirit Lake Road

City

Lot 11662 W. Spirit Lake Road

Blk

Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
BENTONITE	0	19	8 SACKS	DRY POUR

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 19Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	+1	19	0.250	STEEL	☒	☐	☒	☐
4	-10	210	0.160	PVC	☐	☒	☒	☐
					☐	☐	☐	☐

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

- ☐ Perforations? Method
☒ Screens? Screen Type PVC

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
170	210	40		4	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

25 ft. below ground. Artesian pressure lb.
 Depth flow encountered 190 ft. Describe access port or
 control devices: STEEL CAP WELDED

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
25 GPM	100%	210	1 HOUR

Water Temp. COLD Bottom hole temp. COLD

Water Quality test or comments: (below) Depth first Water Encountered 190

CLOUDY, NEEDS TO BE PUMPED

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	19	Decomposed granite	☐	☒
6	19	165	Decomposed granite	☐	☒
6	165	210	Broken decomposed granite	☒	☐

Completed Depth 210 (Measurable)

Date: Started 11/21/02 Completed 11/22/02

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
 complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414

Firm Official and Date 12/3/02

Supervisor or Operator Timothy R. Volking Date 12/3/02

53 N 5W 14