

RECEIVED
MAY 03 2001IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

IDWR/North

1. WELL TAG NO.

DRILLING PERMIT N 768397

Other IDWR No D0017050

2. OWNER:

Name Chris Miller

Address 801 N 7th Street

City Coeur d'Alene

State ID

Zip 83814

3. LOCATION OF WELL by legal description:

N		Twp	54N	North	☒ or	South	☐
Rge		02W	East	☐ or	West	☒	
Sec		32	1/4	NW	1/4	NE	1/4
Gov't Lot		County		Bonner			
Lat		Long					
Address of Well Site: (see next line)							

Carywood to Collins Rd, go left

City

Lot Blk Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	5	Dry pour

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 18Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	18	0.250	Steel	☒	☐	☐	☐
4	10	380	0.165	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe 20 Length Tailpipe 370

9. PERFORATIONS/SCREENS

☒ Perforations? Method Drill☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
340	380	.040	200		PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

20 ft. below ground. Artesian pressure lb.

Depth flow encountered 362 ft. Describe access port or

control devices: Steel cap, welded

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
25	100%	375	1 hr.

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 60
clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	18	Granite, salt/pepper, soft	☐	☒
6	18	54	Granite, salt/pepper, soft	☐	☒
6	54	60	Decomposed granite - (.5-1 GPM)	☒	☐
6	60	79	Granite - salt/pepper, soft	☐	☒
6	79	80	Granite - broken (2 GPM)	☒	☐
6	80	120	Granite - salt/pepper, soft	☐	☒
6	120	234	Granite - pink/green - soft	☐	☒
6	234	237	Granite - broken (2 GPM)	☒	☐
6	237	295	Granite - pink/green, soft	☐	☒
6	295	298	Graite - broken (3 GPM)	☒	☐
6	298	350	Granite - pink/green - soft	☐	☒
6	350	355	Granite - broken (7 GPM)	☒	☐
6	355	362	Granite - pink/green	☐	☒
6	362	365	Granite - broken (10 GPM)	☒	☐
6	365	380	Granite - green soft	☐	☒

RECEIVED

MAY 25 2001

Department of Water Resources

Completed Depth 380 (Measurable)

Date: Started 3/29/01 Completed 4/2/01

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc Firm No 414

Name Date 4/3/01

Firm Official and Date 4/3/01

Supervisor or Operator Curtis S. Hammond Date 4/3/01

FORWARD WHITE COPY TO WATER RESOURCES