

OFFICE USE ONLY

Inspected by TDK Use Typewriter
Twop 54N Page 5W Ball Point Pen
1/4 SE 1/4 SE 1/4


Other IDWR No.

Name James & Nanette Miller

Address P.O.Box 603

City Spirit Lake State ID Zip 83869

Sketch map location must agree with written location.



Twp. 54 North ☒ or South ☐
 Rge. 5 East ☐ or West ☒
 Sec. 15, $\frac{1}{4}$ SE $\frac{1}{4}$ SE $\frac{1}{4}$
10 acres 40 acres 160 acres
 Gov't Lot _____ County Bonner

Address of Well Site Walker Rd

City

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
bentonite	0	18	6	dry

Was drive shoe used? Y ☒ N ☐

Was drive shoe seal tested? Y ☐ N ☐ How?

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1 1/2	20	250		☒	☐	☐	☐
4	-4	20 1/4	160		☐	☒	☐	☐ M
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

☒ Perforations Method Saw
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
164	204	1/8	25			☐	☒
						☐	☐
						☐	☐

14 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or
control devices: cap

SESE 15

SESE 15 54N SW

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10		204	2hr

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments:

Water

[illegible]

Completed Depth 204 (Measurable)
Date: Started 8-26-94 Completed 8-29-94

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Bronson Water Wells Firm No. 360

Firm Official A.D. Benson Date Aug 29, 94

and

Supervisor or Operator _____ Date _____

(Sign once if Firm Official & Operator)