

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4	1/4	1/4	
Lat : : _____	Long : : _____		

1. WELL TAG NO. D0022749

DRILLING PERMIT N 787385

Other IDWR No _____

2. OWNER:

Name Andrew Murphy

Address 2416 Wolf Lodge Creek

City Coeur d'Alene

State ID _____

Zip 83814

3. LOCATION OF WELL by legal description:

N		Twp	50N	North	☒ or	South	☐
W		Rge	02W	East	☐ or	West	☒
E		Sec	32	1/4 SW 1/4	NE 1/4		
S				10 Ac	40 Ac	160 Ac	
		Gov't Lot	County <u>Kootenai</u>				
		Lat	Long _____				

Address of Well Site: (see next line)

2416 Wolf Lodge Road

City Coeur d'Alene

Lot _____ Blk _____ Sub. Name (see next line)

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
10	100%	99	1 HOUR

Water Temp. COLD Bottom hole temp. COLD

Water Quality test or comments: (below) Depth first Water Encountered 18

CLEAR, COLD, NO SMELL

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	8	GRAVEL	☐	☒
8	8	50	SHALE - GRAVEL - BROWN	☒	☐
8	50	58	SHALE - BLUE/GRAY - MEDIUM	☐	☒
6	58	100	SHALE - BLUE/GRAY - MEDIUM	☐	☒

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Grout	0	19	250 LBS	Pumped in

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrded
6	2	58	0.250	STEEL	☒	☐	☒	☐
4	50	60	0.165	pvc	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____

☒ Screens? Screen Type PVC

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
60	100	20		4	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

1 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 18 ft. Describe access port or

control devices: STEEL CAP WELDED

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc. Firm No 414

Name _____

Firm Official Timothy J. Valby Date 10/7/02

Supervisor or Operator Jason C. Beckham Date 10/7/02

RECEIVED
OCT 29 2002
IDWR/North

Completed Depth 100 (Measurable)

Date: Started 10/2/02 Completed 10/3/02

50N 2W . 32.