

RECEIVED

Form 238-7
11/9

SEP 07 2000

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat: : :	Long: : :	

IDWR/North

1. WELL TAG NO. D0013679

DRILLING PERMIT NO

Other IDWR No. 766467

2. OWNER:

Name Terry Hiatt

Address 5875 Evernade

City Hayden LK

State ID

Zip 83835

3. LOCATION OF WELL by legal description:

N	Twp	52N	North	☒ or	South	☐
	Rge	03W	East	☐ or	West	☒
	Sec	34	1/4	NW	1/4	NE
			10 Ac	40 Ac	160 Ac	
	Gov't Lot		County	Kootenai		
	Lat		Long			

Address of Well Site: (see next line)

E Hayden Lake Road to Triangle, first drive on right City

Lot Blk Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	4 sacks	pour in

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 18

Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	18	0.250	Steel	☒	☐	☒	☐
4	10	220	0.165	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

- ☐ Perforations? Method
☒ Screens? Screen Type PVC

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
180	220	.040			PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

40 ft. below ground. Artesian pressure lb.
Depth flow encountered 189 ft. Describe access port or control devices: Steel cap welded

11. WELL TESTS

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
17	100%	215	1 hr.

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 189

clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	18	Decomposed granite	☐	☒
6	18	28	Decomposed granite - firm	☐	☒
6	28	80	Granite - black & white - med hard	☐	☒
6	80	189	Granite - green & white- med hard	☐	☒
6	189	195	Decomposed granite - 17 gpm	☒	☐
6	198	220	Granite - green & white - medium	☐	☒
				☐	☐
				☐	☐
				☐	☐

RECEIVED

OCT 20 2000

Department of Water Resources

Completed Depth 220 (Measurable)

Date: Started 9/5/00 Completed 9/5/00

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc.

Firm No 414

Firm Official and *Tim M. Volkmann*

Date 9/6/00

Supervisor or Operator Curtis S. Hammond

Date 9/6/00

FORWARD WHITE COPY TO WATER RESOURCES

332

52N 3W 34