

RECEIVED

Form 238-7

AUG 04 1998

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 78045

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	

NORTHERN REGION

1. WELL TAG NO. D0005155

DRILLING PERMIT N 96-98-N-137

Other IDWR No

2. OWNER:

Name Mike Madsen

Address 124 Gunnell RD

City Winlock State Washington Zip 98596

3. LOCATION OF WELL by legal description:

N		Twp	53N	North	☒ or	South	☐
W		Rge	03W	East	☐ or	West	☒
E		Sec	07	1/4 SE	1/4 SE	1/4	
S				10 Ac	40 Ac	160 Ac	
		Gov't Lot	County Kootenai				
		Lat	Long				

Address of Well Site: (see next line)

54 West, first rd to R past Clagstone

City

Lot Blk Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	9 sacks	pour in

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s)

Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6"	2	523	0.025	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations? Method air perforator
☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
-500	-520	1"	200		Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

468 ft. below ground. Artesian pressure lb.

Depth flow encountered 468 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
20+	100%	520	1 hr.

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 463

clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks. Lithology, Water Quality and Temperature	Water
8"	0	1	Topsoil	☐ Y ☒ N
8"	1	65	Sand & gravel & cobbles	☐ Y ☒ N
8"	65	198	Sand & gravel - 3/4 minus	☐ Y ☒ N
8"	198	281	Sand & gravel - 3/8 minus	☐ Y ☒ N
8"	281	370	Sand & gravel - 3/4 minus	☐ Y ☒ N
8"	370	420	Sand & gravel - 3/8 minus	☐ Y ☒ N
8"	420	450	Sand & gravel - 3/8 minus	☐ Y ☒ N
8"	450	463	Gray clay - some gravel	☐ Y ☒ N
8"	463	523	Sand & gravel - 3/4 minus	☒ Y ☐ N

Completed Depth 523 (Measurable)

Date: Started 7/27/98 Completed 7/30/98

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc. Firm No 414

Name Date 7/31/98

Firm Official and Date 7/31/98

Supervisor or Operator Jason C. Beckham Date 7/31/98

FORWARD WHITE COPY TO WATER RESOURCES


53N 3W 7

SCANNED

JUL 15 2009

95-10826

MADSEN PIN 0-6315-002-002-0



95-10826

SCANNED
JUL 15 2009