Form 238-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

RECEIVED
MAY 12 2003
IDWR/North

Office Use Only
Inspected by _____
Twp ____ Rge ____ Sec ____
____ 1/4 ____ 1/4 ____ 1/4
Lat: : : Long: : :

1. WELL TAG NO. D 0028171
DRILLING PERMIT NO. 79848
Other IDWR No. _____

2. OWNER:
Name Mike Woodard
Address South 10612 Kiesling Road
City Spokane State Wa Zip 99220

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

POSTED

N / W / E / S — X

Twp. 49 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 31, ____ 10 acres 1/4 N/W 40 acres 1/4 S/W 160 acres 1/4
Gov't Lot ____ County _____
Lat: : : Long: : :
Address of Well Site 12 miles south of Coeur d'Alene
(Give at least name of road + Distance to Road or Landmark)
City Coeur d'Alene

Lt. _____ Blk. _____ Sub. Name _____

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	36	125 lb	Pour around pipe

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 398
Was drive shoe seal tested? ☒ Y ☐ N How? Air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-398	250	Steel	☒	☐	☒	☐
4"	-5	400	160	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS
Perforations Method Torch
Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-330	-375	1/8 X 1'	25	6"	Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
22 ft. below ground Artesian pressure ____ lb.
Depth flow encountered 360 ft. Describe access port or control devices: Well Cap

11. WELL TESTS:
☐ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15 gpm	Airlift	from	400'
	8 hrs		

Water Temp. 50 degrees Bottom hole temp. _____
Water Quality test or comments: Slightly cloudy, no odor
Depth first Water Encounter 200

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8"	0	12	Clay - tan		
	12	27	Sand - tan		
	27	45	Sandy, clay, tan		
	45	59	Granite, brown, decomposed		
	59	200	Granite, Black & white		
	200	205	Granite, black	x	
			1 gpm		
	205	213	Granite, black		
	213	322	Granite, black & white		
	322	324	Granite, Black & white	x	
			2 gpm		
	324	360	Granite, black & white		
	360	363	Granite, black & white	x	
			12 gpm		
	363	400	Granite, black & white		
			15 gpm Total at 400 ft.		

Completed Depth 400' (Measurable)
Date: Started 4-14-03 Completed 4-25-03

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name All-Ways Drilling Inc Firm No. 510
Firm Official Stanley K. Wolfe Date 5-5-03
and
Driller or Operator Alvin Carris Date 5-5-03
(Sign once if Firm Official & Operator)

49N 4W 31

FORWARD WHITE COPY TO WATER RESOURCES