

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

USE TYPEWRITER OR
BALLPOINT PEN

State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name Russell & Pamela Woodworth
Address 985 S. Meadowbrook Acres
Drilling Permit No. 95-92-N-75
Water Right Permit No. _____

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Well diameter increase
☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED

☒ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
1/4 inches	8 inches	+ 2 feet	43 feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
PVCLINER inches	6 inches	- 4 feet	80 feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? PVC LINER ☒ Yes ☐ No
How perforated? ☐ Factory ☐ Knife ☐ Torch ☐ Gun
Size of perforation 1/8 inches by 6 inches SKILSAW
Number _____ From _____ To _____
30 perforations 60 feet 80 feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet

Well screen installed? ☐ Yes ☐ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Gravel packed? ☐ Yes ☐ No ☐ Size of gravel _____
Placed from _____ feet to _____ feet
Surface seal depth 40 Material used in seal: ☐ Cement grout
☒ Bentonite ☐ Puddling clay ☐ _____
Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing
☒ Overbore to seal depth
Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent
Weld
☐ Cemented between strata
Describe access port _____

7. WATER LEVEL

Static water level 57' feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature _____ °F. Quality _____
Describe artesian or temperature zones below.

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
6-8	80	1

9. LITHOLOGIC LOG

079725

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
10	0	10	Top soil		X
10	10	38	Clay brown		X
10	38	43	Basalt hard black		X
8	43	57	Basalt hard black		
8	57	68	Basalt soft black	X	
8	68	75	Basalt broken black	X	
8	75	80	Basalt hard black		X

8" Drive shoe utilized

RECEIVED
JUN 2 9 1992
Department of Water Resources

RECEIVED
JUN 15 1992
NORTHERN REGION
IDWR

6. LOCATION OF WELL

Sketch map location must agree with written location.
Subdivision Name MICROFILM
Lot No. _____ Block No. _____
County KOOTENAI
SW ¼ SW ¼ Sec. 21 T. 50 N 4 E 4
S 4 R. 4 W 4

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
complied with at the time the rig was removed.
Firm Name Ponderosa Drilling Firm No. 228
Address E. 6010 Broadway Date 6-9-92
Signed by (Firm Official) W. Scott Barratt
and James Doyle
(Operator)