

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long
:	:	:	:

1. WELL TAG NO. D0028212

Drilling Permit No: 795175

Other IDWR No.

2. OWNER


Name BOTAI, BOB

Address 1316 SAN JOSE WAY

City PETALUMA State CA Zip 94954

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

Twp. 52 ☒ North or ☐ SouthRge. 4 ☐ East or ☒ West

Sec. 16 1/4 SE 1/4 SE 1/4

Gov't Lot County KOOTENAI

Lat: : Long: :

Address of Well Site 4756 DIAGNAL RD.

City RATHDRUM

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

check all that apply (Replacement, etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
DRY GRANULE				
BENTONITE	0	18	6 BAGS	OVERBORE

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) R.B.Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	362	.250	STEEL	☒	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

- ☐ Perforations Method
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

300 ft. below ground Artesian pressure lb.

Depth flow encountered 350 ft. Describe access port or control devices:

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
20 - 30			1 HR

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: CLEAR

Depth first Water encountered 300

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
8	0	3	Top Soil	☐	☒
8	3	16	Sand & Gravels	☐	☒
8	16	61	Sand, Gravel w/ Cobble	☐	☒
8	61	249	Sand & Gravels	☐	☒
8	249	300	Coarse Sands	☐	☒
8	300	362	Sand & Gravels	☒	☐

Completed Depth 362 (Measurable)

Date: Started 3/12/03 Completed 3/13/03

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official [Signature] Date 3-17-03

and

Supervisor or Operator [Signature] Date 3-14-03

(Sign Once if Firm Official and Operator)

Todd Morgan

52N 4W 16