

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____		1/4 _____	
Lat: _____	: _____	Long: _____	: _____

1. WELL TAG NO. D0033773

DRILLING PERMIT NO 814644
Other IDWR No. _____

2. OWNER:

Name Angie Bridge
Address 15948 Crystal Springs Road

City Rathdrum State ID _____ Zip 83858

3. LOCATION OF WELL by legal description:

N W E S									

Twp 51N North ☒ or South ☐
Rge 05W East ☐ or West ☒
Sec 03 1/4 SE 1/4 NW 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot _____ County Kootenai
Lat _____ Long _____
Address of Well Site: (see next line)

Winch Road _____ City Rathdrum
Lot _____ Blk _____ Sub. Name (see next line) _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite Grans	0	20	8 sacks	Pour In

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____
Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	227	0.250	Steel	☒	☐	☒	☐
4	227	660	0.165	PVC	☐	☒	☒	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____
☒ Screens? Screen Type PVC Johnson

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
660	700	.200		4	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

320 ft. below ground. Artesian pressure _____ lb.
Depth flow encountered 380, 585, 690 ft. Describe access port or control devices: Steel Cap Welded

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
5.5	100%	700	1 Hour

Water Temp. _____ Cold _____ Bottom hole temp. _____ Cold _____
Water Quality test or comments: (below) Depth first Water Encountered 380
Cold, Clear, and No Smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	1	Topsoil	☐	☒
8	1	222	Sand and Gravel Fine	☐	☒
8	222	227	Granite: Brown and White	☐	☒
8	227	255	Granite: Brown and White Medium	☐	☒
8	255	320	Granite: Purple/Black/White Medium	☐	☒
8	320	340	Granite: Dark Purple/Black/White Soft	☐	☒
8	340	402	Granite: Brown/White/Black Soft 0.5GPM	☒	☐
8	402	450	Granite: Purple/Black/White Hard	☐	☒
8	450	480	Granite: Purple/Black/White Soft	☐	☒
8	480	530	Granite: White/Purple/Black Medium	☐	☒
8	530	570	Granite: Dark Purple/Black Hard	☐	☒
8	570	580	Granite: White/Brown/Black Soft	☐	☒
8	580	588	Granite: Green/White/Black Soft 3GPM	☒	☐
8	588	597	Granite: Light Purple/White/Black	☐	☒
8	597	630	Granite: Dark Purple/Black	☐	☒
8	630	670	Granite: Light Purple/White/Black	☐	☒
8	670	700	Granite: Dark Purple/Black Soft 2GPM	☒	☐

RECEIVED
JUN 15 2004
IDWR North

Completed Depth 700 (Measurable)
Date: Started 5/10/04 Completed 5/12/04

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official Jason C. Beckham Date 5/13/04
Supervisor or Operator Jason C. Beckham Date 5/13/04

SCANNED

MAY 22 2007

51N SW 3