

170+

State of Idaho License and Certificate of Water Right

Water License No. G-25900 Amount 1.75 c.f.s.
Water District No. _____ Priority Aug. 12, 1955

THIS IS TO CERTIFY that COEUR d'ALENE PUBLIC GOLF CLUB, INC.
of Coeur d'Alene, Idaho, made application for a permit to appropriate the
public waters of the State of Idaho, dated August 12, 1955; that Permit No. G-25900
was issued under said application; that Certificate of Completion of works, with a carrying capacity of
1.75 second feet, was issued thereunder on September 29, 1961, showing that said works
were completed on the 26th day of August, 1960; and that on the 26th
day of August, 1960,
COEUR d'ALENE PUBLIC GOLF CLUB, Inc.
of Coeur d'Alene, State of Idaho, made proof to the satisfaction of the
State Reclamation Engineer of Idaho, of the right to use the waters of a well
a tributary of subterranean flow, for the purpose of irrigation & domestic
use, under Use Permit No. G-25900 of the Department of Reclamation
and that said right to the use of said waters has been perfected in accordance with the laws of Idaho,
and is hereby confirmed by the State Reclamation Engineer of Idaho and entered of record in Volume
11 of Licenses at page 7170, on the 29 day of September, 1961;
The right hereby confirmed dates from August 12, 1955;

The Point of Diversion is located
in the SE 1/4 SW 1/4 Sec. 3, Twp. 50 N, R. 4 W, B. M. County Kootenai
That the amount of water to which such right is entitled and hereby confirmed, for the purposes
aforesaid, is limited to an amount actually needed and beneficially used for said purposes, and shall
not exceed 1.75 cubic feet per second.

Description and location of use:

Twp.	Range	Sec.	Forty-acre Tract	No. Acres Described in Permit	No. Acres Actually Irrigated
50 N.	4 W.	3	SW 1/4 NE 1/4	15	20
			NE 1/4 SW 1/4	30	40
			SE 1/4 SW 1/4	30	20
			NE 1/4 SE 1/4	10	10
			NW 1/4 SE 1/4	30	40
			SW 1/4 SE 1/4	15	20
			SE 1/4 SE 1/4	1	10
			Total number of acres to be irrigated:		160

The right to the use of the water aforesaid hereby confirmed is restricted to the lands or place
of use herein described, as provided by the laws of Idaho.

WITNESS the seal and signature of the State Reclamation Engineer, affixed at Boise, Idaho, this
29th day of September, 1961.

(SEAL)

HAL H. W. THOMAS
Deputy State Reclamation Engineer.

2 homes w/ clubhouse (?)


STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE

REPORT OF ENGINEER

PERMIT NO 0-25900

REPORT ON PROOF OF Completion of Works & Beneficial Use

Martin Chesnut, President
Coeur d'Alene Public Golf Course
1212 Montana Avenue
Coeur d'Alene, Idaho



Scale: 2 Inches Equals 1 Mile. Draw Map In Ink.

475
87 1/2 25900

STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE, IDAHO
REPORT OF ENGINEER

Permit No. Q-25900

This proof is for Completion of Works & Beneficial Use In Water District No. _____

1. Name of applicant Coeur d'Alene Public Golf Course

2. Source of water supply: Subterranean

3. Location of point of diversion: Is in the SE 1/4 of Section 3

T. 50°N. R. 4°W. County of Kootenai

4. Describe works as they exist, giving dimensions and capacities of same: Wash - 50 HP U.S. Motor #1088887, B.T. Pump #333275 170' x 6" Column 6" discharge reduced to 5" main. - East - 75 HP U.S. Motor #981846, Berkeley Pump #5607877, 170' x 8" Column 8" discharge into 8" main. Domestic - 7 1/2 HP B.T. Submersible #315289, 2" discharge to 1000 gallon storage tank @ 65' pressure (rated @ 50 gpm @ 65')

5. Water is used for: Irrigation and domestic

6. State whether or not water has been turned into works of diversion: yes

7. List legal subdivisions of lands to be irrigated. If proof is for beneficial use, give exact number of acres under cultivation in each forty-acre tract. (Describe manner and place of use if other than irrigation):

SW 1/4, E 1/4, NW 1/4, SE 1/4, Sec. 3, T. 50 N., R. 4 W., B.M.

Attached photo stat plat shows approx 10 acres NW 1/4, SE 1/4 and 10 acres SE 1/4 SE 1/4.

Well is hand dug 182' deep x 5' dia. - 48' x 24' steel perforated liner on bottom with gravel pack above steel liner well is lined with concrete brick that has a diameter of 3'-2" with steel plate on top with all 3 pumps mounted on top. (h: 159')

(Submit map on attached plat, showing location and details of above description.)

8. What large stream would the water here appropriated finally reach?

Remarks: Mr. William Harshaw, greenskeeper, a long

Pumps noted at time of examination. Pumps had been measured separately by Al Wild, mgr. Idaho Water, with a Pitot gage at the nozzle.

This examination was made on the 11th day of September, 1961

(Signed) Lynn Johnson Examiner

25900

INSTRUCTIONS TO EXAMINERS

1. Always carefully note the location of the point of diversion and accurately plat same.
2. When proof is for beneficial use, carefully check up the number of acres actually irrigated in each forty and accurately plat same.
3. Make a map showing the correct location of streams and ditches, and the irrigated lands, and any adjacent permanent landmarks, such as towns, lakes, large streams and public roads.
4. If any unusual conditions are discovered, make plain statement of them under remarks.
5. Always see the holder, if possible, and go over the whole ground with him and make your report only upon actual existing facts and conditions.
6. Give general characteristics of soils, topography, and crops raised.

RECEIVED

SEP 20 1961

Department of Reclamation

410
4-3567
1/25/65
MELVIN CHAMBERLAIN, owner
Four Adams Mobile Golf Course
1212 Montana Avenue
Georgetown, Idaho
Permit No. 6-29909

Examination for Completion of Works & Beneficial Use

County Kootenai

Sec. 3 T. 50N. R. 4W

Quantity: 1.75 cfs

Source: Well

P.D.: SE. 51W, Sec. 3, T. 50N. - R. 4N.E.

Use: Irrigation & domestic

Filed: Aug. 12, 1955

Due: Sept. 2, 1960

Extension: _____

Completion of Works: _____

Other Rights: none

6PM 480 - 575
9PM 520 - 750
1000

1.11

2.22 cfs

Measure by pilot gauge by A.I.E. with
delayed water meter (continuous)

Well Hand dug 5' dia
cannon drill

3' 6" diam 15' 4' 48" x 4' 48" dia
perforated liner to bottom of
water gravel pack.

170' pay column

East Pump

48 gpm

50 HP US Motor # 1088887, B.J. Pump

338275 - 6" X

column Redwood
to 5m main

East Pump

520 gpm

75 HP US Motor # 981846, Berkeley

Pump # 5607877 - 8" X column

for connection

7 1/2 HP B.J. submersible # 315289

1000 gal storage tank 65 ft pressure
Rated at 50 gpm @ 65 ft

	9	1422 X 260 - 3.5	
1	942 X 180 - 3.9	10	981 X 240 - 5.6
2	372 X 120 - 1.2	11	525 X 240 - 3.1
3	1419 X 280 - 9.1	12	1240 X 240 - 7.1
4	1107 X 160 - 4.1	13	1195 X 240 - 6.6
5	948 X 140 - 3.1	14	1020 X 240 - 5.6
6	487 X 240 - 2.7	15	561 X 240 - 3.1
7	1230 X 280 - 7.9	16	1275 X 240 - 7.1
8	984 X 180 - 4.1	17	1000 X 240 - 5.5
		18	1401 X 240 - 7.7



35.9
William Harslow along - 6000 ft
Keoper

$$6 - \frac{1}{2} \times \frac{1}{4} = 65.4$$

$$7 - \frac{1}{2} \times \frac{1}{32}$$

$$4 - \frac{5}{16} \times \frac{5}{32}$$


17



undboes 16
SS

0 0

0065900



Plot	Area	Perimeter
1	4.4	144
2	4.4	144
3	9.0	144
4	4.4	144
5	3.4	144
6	6.6	144
7	8.5	144
8	8.0	144
9	4.4	144
10	5.6	144
11	3.0	144
12	7.0	144
13	6.6	144
14	5.6	144
15	3.0	144
16	7.0	144
17	5.5	144
18	4.4	144
Total	144.0	144.0