RECEIVED
MAY 19 1995
NORTHERN REGION
IDWR
POSTED

Form 238-7
7/94

W.I.C.

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 95 - 95 - C - 0008 - 000
Other IDWR No. ~~95-08891~~

2. OWNER:
Name COEUR D'ALENE GOLF COURSE
Address PO BOX 5098
City COEUR D'ALENE State ID Zip 83814

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

Twp. 50 North ☒ or South ☐
Rge. 04 East ☐ or West ☒
Sec. 03 NW 1/4 NW 1/4 SE 1/4
(NW 10 acres; NW 10 acres; SE 160 acres)
Gov't Lot ____ County KOOTENAI

Address of Well Site GOLF COURSE
City ____
(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name ____

4. PROPOSED USE:
☐ Domestic ☐ Municipal ☐ Monitor ☒ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

5. TYPE OF WORK
☒ New Well ☒ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	100	6 BAGS	SLURRY
			Top off	w/dry

Was drive shoe used? ☐ Y ☐ N Shoe Depth(s) ____
Was drive shoe seal tested? Y ☐ N ☐ How? ____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
12	+3	352	.250	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method ____
☒ Screens Screen Type S/S TELE

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
290	330			12"		☐	☐
						☐	☐
see	attached info					☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
170 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices: ____

NWNWSE 3 50N 4W

11. WELL TESTS:
☒ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
?			
350+			

Water Temp. ____ Bottom hole temp. ____
Water Quality test or comments: ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
16	0	16	GRAVEL & SAND W/SOIL 2" MINUS		X
14	16	62	GRAVEL & SAND W/SOIL 2" MINUS		X
14	62	83	SAND & GRAVEL 3/8 MINUS		X
14	83	89	BOULDER		X
14	89	95	SAND COBBLES		X
14	95	109	COBBLES COARSE W/GRAVEL		X
14	95	109	SEAMS W/CLAY BROWN		X
14	109	255	SAND SILT BROWN	X	
14	255	287	SAND FINE BROWN	X	
14	287	298	SILTY SAND CLAY GRAY	X	
14	298	330	SAND W/GRAVEL W/CLAY GRAVEL 3/4 MINUS	X	
14	330	341	SAND LT. BROWN GRAY	X	
14	341	350	SAND SILTY CLAY GRAYISH BROWN		X
14	350	392	SANDY CLAY GRAYISH		X
			Cased to 352 then open hole to 392		
			1 - 12" Shoe		
			1 - Weld on cap		

Completed Depth 392 (Measurable)
Date: Started 03/06/95 Completed 03/14/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

H2O WELL SERVICE, INC. 448
Firm Name ____ Firm No. ____
Firm Official ____ Date 03/20/95
and
Supervisor or Operator ____ Date 03/20/95
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES