

WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long
:	:	:	:

1. WELL TAG NO. D0051938

Drilling Permit No:

Other IDWR No.

2. OWNER

Name JACKLIN, WADE & TANYA

Well Number:

1317

Address 3716 MINERS LOOP

City COEUR D'ALENE State ID Zip 83815

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N	W	E	S	Twp. 51N	☒ North or ☐ South
				Rge. 03W	☐ East or ☒ West
				Sec. 29	1/4 NW 1/4 SW 1/4
Gov't Lot				County KOOTENAI	
Latitude:				Longitude:	

Address of Well Site 3720 NETTLETON GULC

City COEUR D'ALENE

(Give at least name of road + Distance to Road or Landmark)

Lt. 2 Blk. 1 Sub. Name Rod's Barn Acres

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	52	450 lbs	Overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 52Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	52	.250	STEEL	☒	☐	☒	☐
4	-5	140	.200	PVC	☐	☒	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILL SAW☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
105	140	1/8 X 6	70	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

40 ft. below ground Artesian pressure lb.

Depth flow encountered 130 ft. Describe access port or control devices:

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10			1 HR

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: GOOD

Depth first Water encountered 82

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water
10"	0	2	Top Soil	☐ ☒
8	2	22	Brown Clay	☐ ☒
8	22	32	Brown Broken Clay / Shale	☐ ☒
8	32	40	Brown Med. Clay & Sand	☐ ☒
8	40	47	Brown Clay	☐ ☒
8	47	52	Gray Hard Shale	☐ ☒
6	52	82	Gray Hard Shale	☐ ☒
6	82	140	Gray/Brown Broken Shale	☒ ☐

RECEIVED

AUG 07 2007

IDWR/North

Completed Depth 140 (Measurable)
 Date: Started 6/21/2007 Completed 6/22/2007

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official *Robert Kern* Date 6-22-07

and

Supervisor or Operator *Bob Kern* Date 6/22/07

BOB KERN

(Sign Once if Firm Official and Operator)

51N 3W 29