

Use Typewriter
or
Ball Point Pen

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

2. OWNER: FRANK DENKE
Name

Yield gal./min.	Drawdown	Pumping Level	Time
3GPM			

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: _____

N
 W E
 X
 Twp. 52N North ☐ or South ☐
 Rge. 5W East ☐ or West ☐
 Sec. 26 1/4 NE 1/4 SE 1/4
 Gov't Lot _____ County Kootenai

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Water

Lt. _____ Blk. _____ Sub. Name _____

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8	0	14	DECOMPOSED GRANITE BROWN SOFT		X
6	14	38	GRANITE BRWN & WHITE SOFT		X
6	38	63	GRANITE WHITE & BROWNMED SOFT		X
6	63	109	GRANITE BLACK & BRWN WHITE SOFT		X
6	109	147	GRANITE BLACK & COPPER MEDIUM		X
6	147	151	GRANITE BROWN & WHITE MEDIUM		X
6	151	163	GRANITE WHITE & BROWN W/BLACK		X
6	163	170	GRANITE BLACK & WHITE W/COPPER		X
6	170	190	GRANITE WHITE & BLACK MED SOFT		X
6	190	200	GRANITE BLACK & WHITE W/GREEN MED		X
6	200	293	GRANITE BLK & WHITE MED HARD		X
6	293	370	GRANITE BLK & COPPER & GREEN		X
6	370	375	GRANITE BLK & GREEN FRACTURED	X	
6	375	445	GRANITE BLK & COPPER W HITE MED		X
6	445	467	GRANITE WHITE & BLACK MED		X
6	467	540	GRANITE BLACK & COPPER W/ WHITE MEDIUM		X

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

Completed Depth 540' (feet)
Date: Started 08/03/94 Completed 08/04/94

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	7 bags	DRY

Was drive shoe used? ☒ Y ☐ N ☐
Was drive shoe seal tested? ☒ Y ☐ N ☐ How? Drove into Rock

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2.5	18.5	250	Steel	☒	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

Depth flow encountered _____ ft. Describe access port or control devices:

Control devices				
NFSE	26	52N	5W	

FORWARD WHITE COPY TO WATER RESOURCES