

RECEIVED

JAN 08 2010

IDWR / NORTH
**IN THE DISTRICT COURT OF THE FIFTH JUDICIAL DISTRICT OF THE
 STATE OF IDAHO, IN AND FOR THE COUNTY OF TWIN FALLS**

**IN RE THE GENERAL ADJUDICATION
 OF RIGHTS TO THE USE OF WATER FROM
 THE COEUR D'ALENE-SPOKANE RIVER
 BASIN WATER SYSTEM**

CIVIL CASE NUMBER: 49576Ident. Number 95-12998Date Received: 1/8/10Receipt No: NO 23285Received By: JD**NOTICE OF CLAIM TO A WATER RIGHT****ACQUIRED UNDER STATE LAW****For Domestic and/or Stockwater Purposes****Where Daily Use is less than 13,000 gallons per day**1. Name of Claimant(s) Brent ^{Smith} or Vicki Mundlin-Smith Phone (208) 777-1984Mailing Address 817 S. Mariah Way Post Falls, ID Zip 83854
Street or Box City State2. Date of Priority: (Only one per claim) 6-27-91
Month/Day/Year (YYYY)3. Source of water supply (Check one) Ground Water (X) or Other () (a) _____
 which is tributary to (b) _____4. Location of Point of Diversion is: Township 50N., Range 5W, Section 17,
SW 1/4 of NE 1/4, or Govt. Lot _____ BM. County of Kootenai;Parcel (PIN) no. 50N05W-17-1250Additional points of diversion if any: None

If available, GPS coordinates: _____

5. Description of diverting works (Wells, Pumps, Spring boxes, Pipelines, Etc.) including the dates of any changes or enlargements in use, the dimensions of the diversion works as constructed and as enlarged and the depth of each well.

Submersible pump in well

6. Water is claimed for the following: (Limited to Domestic and/or Stockwater uses. See page 1 of the instructions.)

For Domestic purposes from 1-1 to 12-31 amount 0.04 cfs
Month/Day Month/Day cfs() or AFY()

For _____ purposes from _____ to _____ amount _____

7. Total Quantity claimed 0.04 cfs (X) or AFY ()

8. Non-irrigation uses. Describe fully. (eg. Domestic: give number of households served if single ownership;

Stockwater and Number of livestock) 1 home

SCANNED

JAN 11 2010

9. Location of Place of Use is: Township 50N, Range 05W, Section 17
SW 1/4 of NE 1/4, Govt. Lot _____ BM. Parcel (PIN) no. 50N-05W-17-1250
If different than shown in Item 4
for (Check One) Domestic (☒) Stock () Domestic and Stock ()

Additional places of use, if any None

10. In which county (ies) are lands listed above as place of use located? Kootenai

11. Do you own the property listed above as place of use? Yes (☒) No ()
If the answer is No, describe in Remarks below the authority you have to claim this water right.

12. Describe any other water rights used at the same place and for the same purposes as described above.

None or None (☒)

13. Remarks:

14. Basis of Claim (Check One) Beneficial Use (☒) Posted Notice () License () Permit () Decree ()

Court _____ Decree Date _____ Plaintiff v. Defendant _____

If applicable provide IDWR Water Right Number _____

15. Signature(s)

(a.) By signing below, I/We acknowledge that I/We have received, read and understand the form entitled "How you will receive notices in the Coeur d'Alene-Spokane River Basin Adjudication." (b.) I/We do () do not () wish to receive and pay a small annual fee for monthly copies of the docket sheet.

Number of attachments: 1

For Individuals: I/We do solemnly swear or affirm under penalty of perjury that the statements contained in the foregoing document are true and correct.

Signature of Claimant (s) Rupa Munder Smith Date: 1-4-10
Date: _____

For Organizations: I do solemnly swear or affirm under penalty of perjury that I am

_____ of _____,
Title Organization

that I have signed the foregoing document in the space below as

_____ of _____,
Title Organization

and that the statements contained in the foregoing document are true and correct.

Signature of Authorized Agent _____ Date _____

Title and Organization _____

16. Notice of Appearance:

Notice is hereby given that I, _____, will be acting as attorney at law of behalf of the claimant signing above, and that all notices required by law to be mailed by the director to the claimant signing above should be mailed to me at the address listed below.

Signature _____

Address _____

Date _____

Last Name _____ Identification No. _____

SCANNED

JAN 11 2010

UNITED PUMP COMPANY

SALES • SERVICE • INSTALLATION
FOR SUBMERSIBLE • SEWAGE • IRRIGATION
LICENSED ELECTRICAL CONTRACTOR

OCTOBER 10, 1996

KATHERINE HANNA
PRUDENTIAL ACUFF NW REAL ESTATE
1103 EAST SHERMAN
COEUR D'ALENE, ID 83814

RE: WELL EVALUATION REPORT ORDERED BY BRENT SMITH.

PROPERTY LOCATION: 2401 SIGNAL POINT ROAD, POST FALLS, ID 83854.

KATHERINE:
AS REQUESTED, PLEASE FIND THE FOLLOWING WELL EVALUATION REPORT FOR
THE ABOVE MENTIONED PROPERTY TAKEN ON OCTOBER 9, 1996.

WELL EVALUATION REPORT

WELL CONSTRUCTION INFORMATION INFORMATION TAKEN FROM: WELL DRILLER'S REPORT

WELL DRILLED BY: UNITED DRILLING INC., HAYDEN, ID
DATE DRILLED: JUNE 27, 1991
DRILLING PERMIT NUMBER: 95-91-N-91
ORIGINAL WELL OWNER'S NAME: BOB SCHMAND\NORTH IDAHO REALTY
LEGAL DESCRIPTION OF WELL LOCATION: SEC.17 TN.50N R.5W
PURPOSE OF WELL: DOMESTIC WATER
DIAMETER OF WELL AT SURFACE: 6"
TOTAL DEPTH OF WELL: 700'
DIAMETER AND FOOTAGE OF STEEL CASING: 20'
DIAMETER AND FOOTAGE OF WELL LINER: 4" PVC\690'
DEPTH OF LINER PERFORATIONS OR SCREENS: PERFORATED FROM 580' TO 680'
STATIC WATER LEVEL: 190'
WELL GPM AND HOURS PUMPED: ESTIMATED FROM 6 TO 10 GPM FOR 1 HOUR

CONDITION OF WELL AS NOTED: NORMAL

COMMENTS: SOME SETTLING OF THE GROUND HAS OCCURRED. GRADE AROUND
THE WELL SHOULD BE RAISED APPROXIMATELY 1'.

PUMP SYSTEM INFORMATION

WELL PUMPING SYSTEM

DATE OF INSTALLATION: UNKNOWN (ESTIMATED 1991)
5 YEAR MANUFACTURES WARRANTY: UNKNOWN
UNIT HORSE POWER: 3HP
BRAND PUMP: UNKNOWN MODEL PUMP: 10 GPM SERIES?
BRAND MOTOR: FRANKLIN VOLTAGE\PHASE: 230V\1 PHASE

CONTROL BOX USED: FRANKLIN WITH CONTACTOR
DROP PIPE SIZE AND TYPE: 1" GALVANIZED ?
PITLESS ADAPTER SIZE AND TYPE: 1 1/4" HEAVY BRASS
WELL SEAL OR WELL CAP: WELL SEAL
SUBMERSIBLE WIRE SIZE AND TYPE: #4 GAGE COPPER
DISTANCE FROM WELL TO HOUSE: 150' APROX.
NUMBER OF YARD HYDRANTS: DID NOT CHECK
PRESSURE TANK(S) SIZE AND BRAND: 86 GALLON WELL-RITE #WR-260
AIR CHARGE IN TANKS: 34 PSI
PRESSURE GAGE: YES PRESSURE RELIEF VALVE: YES HOSE BIBB: YES
PRESSURE SWITCH SETTING: DID NOT CHECK
LOCATION OF PRESSURE TANK AND CONTROLS: BASEMENT
SIZE AND LOCATION OF HEATER:
LIGHTING AVAILABLE:
LOAD CENTER SIZE AND TYPE:

RESERVOIR AND BOOSTER PUMP INFORMATION

RESERVOIR TYPE AND SIZE:NA
GENERAL CONDITION OF RESERVOIR:NA
TYPE OF RESERVOIR ACCESS:NA
CONDITION OF RESERVOIR ACCESS SEAL:NA
RESERVOIR VENT:NA
BOOSTER PUMP:NA

TEST RESULTS. INFORMATION. COMMENTS

WELL PUMP FLOW: FROM 15 TO 5 GPM, AVERAGE OF 9.42 OVER 4 HOURS.
WELL PUMP SHUT OFF PRESSURE: 200+ PSI (GOOD)
COMMENTS: WELL PUMP PERFORMS AS EXPECTED.

MOTOR READINGS: NORMAL
MOTOR SHORT TO GROUND READING: NONE...GOOD!
AMPERAGE: 15 AMPS...NORMAL
VOLTAGE: 230V
COMMENTS: MOTOR LOOKS NORMAL.

CONDITION OF PRESSURE TANK: EXCELLENT
PROPERLY SIZED PRESSURE TANK: YES
COMMENTS: INSTALLATION LOOKS NORMAL.

GENERAL PLUMBING AND ELECTRICAL COMMENTS:

ELECTRICAL CONTACTOR FOR WELL PUMP SHOULD BE REPLACED PRIOR TO NORMAL
USAGE OF WATER...ESTIMATED COST \$100.00 FOR PARTS AND LABOR.

SCANNED

JAN 11 2010

SUMMARY

IN GENERAL THE SYSTEM LOOKS GOOD, WITH THE EXCEPTION OF THE WELL PUMP CONTACTOR AS NOTED.

THE ISSUE OF SAND COMING FROM THE WELL IS OF SOME CONCERN. AS NOTED ON THE WELL TEST FORM, SOME TRACES OF SAND WERE PRESENT THROUGHOUT THE 4 HOUR WELL TEST. THE AMOUNT OF SAND WAS NEVER WHAT WE WOULD CALL "EXCESSIVE"; HOWEVER, ANY AMOUNT OF SAND MAY SHORTEN THE USABLE LIFE OF THE WELL PUMP. AT THIS TIME THE WELL PUMP CHECKS OUT NORMAL WITH NO VIABLE SIGNS OF DAMAGE FROM SAND.

CERTIFIED BY:


RICHARD A. AGUEROS, PRESIDENT
UNITED PUMP COMPANY

CC: BRENT SMITH
YOUNG'S ELECTRIC SIGH Co., 5000 E. SELTICE, POST FALLS, ID, 83854

SCANNED

JAN 11 2010