

SONOSW-09-1900

PANHANDLE HEALTH DISTRICT I
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

PERMIT FEE \$50.00

PERMIT NO. 6592 PAID CASH CHECK NO FEE DATE 12-28-83
INSTALLATION FOR (NAME) Mark Tiddies SIZE OF LOT 6.7 Acres FT. X FT.
LEGAL DESCRIPTION OF PROPERTY Sec. 9 T50 R5
LOCATION OF INSTALLATION See attached Plot Plan for Complete
U. 985 Riverview Dr.

NO. LIVING UNITS 1 BEDROOMS 5 BATHS 3 1/2 PEOPLE SERVED 4 OTHER _____

SEPTIC TANK 1500 GALS. - DISTANCE TO DWELLING FOUNDATION 5' WELL 50' WATER LINE 10'
SURFACE WATER 50' TYPE OF TANK: CEMENT _____ METAL _____ OTHER _____

DISPOSAL AREA: DRAIN FIELD X ABSORPTION BED _____ OTHER _____ DIMENSIONS 400 sq. ft.

COMPONENT SEPARATIONS:

PROPERTY LINE:

FRONT 5 FT. BACK 5 FT. SIDE 5 FT. DWELLING FOUNDATION 20 FT.
WELL 100 FT. SURFACE WATER 300 FT. SEPTIC TANK 6 FT. NEIGHBOR'S WELL 100 FT.
DEPTH TO GROUND WATER _____ WATER SERVICE LINES 25 FT.

I UNDERSTAND THAT THIS PERMIT IS NON-TRANSFERABLE AND IS VALID FOR 1 YEAR FROM THE DATE OF APPLICATION. DRAINFIELD MUST NOT EXCEED 3 FEET IN DEPTH.

APPLICANT'S SIGNATURE Mark Tiddies APPLICANT IS: ☐ OWNER ☒ CONTRACTOR ☐ OTHER
MAILING ADDRESS P.O. Box 1323 Skyline Park, Ida. PHONE NO. 772-9612
REMARKS _____


PERK RATE _____ MIN./in. SOIL PROFILE _____

LOT PLAN SUBMITTED _____ Date 12/29/83 APPROVED _____ DISAPPROVED _____ Date _____

PERMIT ISSUED BY Anthony Davis REMARKS Community Services Permit #11783 dated 12-28-83

VICINITY MAP
(Show How To Get There From This Office)

PLOT PLAN
(Show House, Other Buildings, Proposed Sewage Layout, Wells, Water Lines, Roads, Streams, Lakes and Distances Between)



THIS OFFICE MUST BE NOTIFIED FOR FINAL INSPECTION 24 HOURS BEFORE COVERING SYSTEM!

INSPECTION - SYSTEM COVERED _____ APPROVED _____ NOT APPROVED _____ Date _____

INSPECTED BY _____ Name _____ INSTALLED BY _____ Name _____ DATE _____

REMARKS _____

REFERENCE: RULES AND REGULATIONS FOR INDIVIDUAL AND SUBSURFACE SEWAGE DISPOSAL SYSTEMS
Idaho Department of Health, Environmental Improvement Division, February 1978

SCANNED
JAN 13 2010