Form 238-7
6/93

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

RECEIVED
MAR 0 4 1994
Department of Water Resources

092290

1. DRILLING PERMIT NO. 95 - 94 - N 32 - 000
Other IDWR No. _____

2. OWNER:
Name LESLIE & JOAN KIRSCH
Address N 100 PLEASANTVIEW RD
City POST FALLS State ID Zip 83854

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

T. 51 North ☒ or South ☐
R. 05 East ☐ or West ☒
Sec. 10, _____ 1/4 SE 1/4 NW 1/4
Gov't Lot _____ County KOOTENAI

Address of Well Site HWY 53
(Give at least Direction + Distance to Road or Landmark)

Lot No. _____ Block No. _____ Subd. Name _____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	40	100gals	POURED

Was drive shoe seal tested? Y☐ N☐ How? _____

8. CASING/LINER:

Diameter	From	To	Guage	Casting	Liner	Steel	Plastic	Welded	Threaded
6"	+2	216	.250			☒	☐	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 216'
Top Packer or Headpipe _____ Bottom Tailpipe _____

9. PERFORATIONS/SCREENS
☐ Perforations Method _____
☐ Screens Type _____ Material _____

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
						☐	☐
						☐	☐
						☐	☐
						☐	☐

SENW 10 S1N SW

10. WELL TESTS:
☐ Pump ☐ Bailer ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
50+			

Temperature of water _____ Was a water analysis done? Yes ☐ No ☐
By whom? _____
Water Quality (odor, etc.) _____
Bottom Hole Temperature _____

11. STATIC WATER LEVEL:
140' ft. below surface Depth artesian flow found _____
Artesian pressure _____ lb. Describe access port _____
Describe Controlling Devices: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
8	0	70	SAND & GRAVEL		
8	70	120	CEMENTED GRAVEL & SAND		140
8	120	137	SAND & GRAVEL W/CLAY SEEMS		
8	137	190	sand & gravel w/CLAY SEEMS W/WATER BROWN		
8	190	216	SAND & GRAVEL COURSE W/WATER	50+	

Date: Started 02/11/94 Completed 02/14/94

RECEIVED
FEB 2 2 1994
NORTHERN REGION
IDWR

FEB 08 1995

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WELL SERVICE INC Firm No. #448
Firm Official Brent McE Date 2-17-94
and
Supervisor or Operator L.E. Date 2-15-94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES

SCANNED
SEP 1 1 2009