

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat:	Long:	

1. WELL TAG NO. D0054441

Drilling Permit No: 850 733
Other IDWR No.

2. OWNER

Name MARKS, WILEY & GLORIA

Address 18401 W. SNAP DRAGON LN

City HAUSER State ID Zip 83854

Well Number:
1399

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N					
W					E
					S

Twp. 51N North or South
Rge. 06W East or West
Sec. 12 1/4 SW 1/4 NE 1/4
Gov't Lot County KOOTENAI
Latitude N47:46:778 Longitude W117:02:041

Address of Well Site SAME

City HAUSER

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	18	450 LBS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 18

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	18	.250	STEEL	☒	☐	☒	☐
4	-5	300	.200	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILL SAW

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
280	300	1/4 X 6	80	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

70 ft. below ground Artesian pressure lb.

Depth flow encountered 70 ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump	☐ Bailor	☒ Air	☐ Flowing Artesian
Yield gal./min.	Drawdown	Pumping Level	Time
5			1 HR

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: CLEAR

Depth first Water encountered 70

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water Y
10	0	10	Sand w/ Gravel	☒
10	10	18	Decomposed Granite	☒
6	18	60	Decomp Tan Granite	☒
6	60	70	Decomp Tan Granite w/ 2gpm	☒
6	70	120	Decomp Tan Granite	☒
6	120	280	Black / White Granite	☒
6	280	300	Black / White Granite	☒

RECEIVED
MAR 07 2008
IDWR/North

SCANNED
SEP 27 2017

Completed Depth 300 (Measurable)
Date: Started 2/25/2008 Completed 2/25/2008

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService Inc. Firm No. 448

Firm Official Date 2-29-08

Supervisor or Operator Date 2/26/2008
JR CANTRELL (Sign Once if Firm Official and Operator)

GIN 124) 17