

Date: September 28, 2017
To: Notice of Claim File 95-16342
From: Linda Werner, Sr. Water Resource Agent *L.W.*
Subject: Field Inspection Findings of September 26, 2017

Accompanied By: Tom Harris, Representative of Trustee Robin Harris
Joseph Carlson, IDWR Staff Engineer

Source: Careywood Creek Tributary to Sinks

Point of Diversion: T54N, R2W, Section 19, SE1/4NE1/4

Water from Careywood Creek is diverted at a point listed above by means of a 7.5 hp electric Wagner pump or a 127 cc gas powered Jayco pump. Irrigation is by handline and sprinklers.

Usage and Quantity: Irrigation: T54N R2W Sec. 19

NENE 3.5

NWNE 2.5

SWNE 1.0

SENE 4.0

Total: 11 Acres @ 0.02 CFS/AC= *0.22 CFS

*A water measurement was not taken. Pump and pipeline were in storage.



Diversion site on Careywood Creek
in SE1/4NE1/4, T54N R2W, Sec. 19





127 cc Gas Powered Jayco Pump



7.5 HP Electric Wagner Pump



Irrigation Pipeline



Looking from south to southwest at place of use in the NE1/4, Section 19, T54N, R2W.