



State of Idaho

DEPARTMENT OF WATER RESOURCES

Northern Region, 7600 N. Mineral Drive, Suite 100 • Coeur d'Alene, Idaho 83815

Phone: (208) 762-2800 • Fax: (208) 762-2819 • Web Site: www.idwr.idaho.gov

C. L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Interim Director

June 15, 2010

Norm Druffel and Sons
2653 Sand RD
Pullman, WA 99163

Dear Claimants:

Thanks for the claim information that you provided to the Idaho Department of Water Resources (IDWR) Northern Region office. Additional information and payment of the Adjudication \$25 filing fee to IDWR is required before the Department can make an accurate recommendation to the Court for the Northern Idaho Adjudication.

Please contact me for an appointment to amend your claim after you have reviewed the enclosed claim photocopy, the attached air photograph, and the enclosed Well Driller's Report. A IDWR well driller's tag with the letter D followed by several numbers should be present on your well. Please check your well to determine what number is shown on the tag. You will need to file a second claim if you are withdrawing water from Lake Coeur d'Alene.

Please mark the location of the well that supplies your home with a dark 'X' labeled 'WELL' and your home circled and labeled 'HOME' on the attached air photo. The completed air photo brought to your appointment or returned to me at the IDWR Northern Region office at the address shown above.

I can be contacted at the address shown above or at (208) 762.2800 if you have any questions. Please note that our office in Coeur d'Alene has moved from our former location on Northwest Avenue to the address shown above.

Respectfully,

Shaun M. Maxey
Senior Water Resource Agent
Idaho Department of Water Resources, Northern Region
7600 Mineral DR, Ste. 100
Coeur d'Alene, ID 83815

Enc

SCANNED
JUN - 7 2011

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

RECEIVED

1. WELL TAG NO. D 0033750
DRILLING PERMIT NO. 816401 JUL 02 2004
Water Right or Injection Well No. _____

IDWR/North

2. OWNER:

Name Bill Minnaugh
Address 24782 S. Cottonwood Bay Lane
City Worley State ID Zip 83876

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 47N North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 4 1/4 45 1/4 45 1/4
Gov't Lot _____
County Kootenai 10 acres 40 acres 160 acres
Lat: : : Long: : :
Address of Well Site Cottonwood Bay Lane
City Worley

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply

(Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>24</u>	<u>20 sacs</u>	<u>Pour</u>

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 75
Was drive shoe seal tested? ☒ Y ☐ N How? air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6" +2</u>	<u>75</u>	<u>.250</u>	<u>Steel</u>	☒	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method _____

Screen Type & Method of Installation _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

30 ft. below ground Artesian pressure _____ lb.
Depth flow encountered 52 ft. Describe access port or control devices: cap

Office Use Only			
Well ID No.			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat: : :	Long: : :		

12. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>100+</u>			<u>2 hr</u>

Water Temp. 56.2 Bottom hole temp. _____

Water Quality test or comments: cloudy no odor

Depth first Water Encounter 52

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8</u>	<u>0</u>	<u>52</u>	<u>Basalt Broken</u>		☒
	<u>52</u>	<u>60</u>	<u>Basalt Broken</u>		☒
<u>1</u>	<u>60</u>	<u>95</u>	<u>Basalt Broken</u>		☒

Completed Depth 95' (Measurable)

Date: Started 6-11-04 Completed 6-15-04

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Appl-Ways Drilling, Inc Firm No. 510

Principal Driller Stan E. Wolfe Date 6/27/04

and Driller or Operator II Doree R. Moll Date 06/27/04

Operator I _____ Date _____

Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.

RECEIVED
MAR - 2 7/11

DRUFFEL PIN 0-1740-000-006-0



SCANNED
MAR - 2 2011