

Form 238-7
9/82



STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

USE TYPEWRITER OR
BALLPOINT PEN

State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name TEO OR SHEILA PULVER
Address 20121 VENTURA BLVD, SUITE 310
Owner's Permit No. WOODLAND HILLS, CA. 91364

7. WATER LEVEL

Static water level 50 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☒ Cap ☐ Plug
Temperature cold °F. Quality Excellent
Describe artesian or temperature zones below.

2. NATURE OF WORK

- ☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

8. WELL TEST DATA

- ☐ Pump ☐ Baller ☒ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>40</u>	<u>Variable</u>	<u>1/2 hr</u>

3. PROPOSED USE

- ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED

- ☒ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
<u>.250</u> inches	<u>6</u> inches	<u>+ 2</u> feet	<u>32</u> feet
<u>PVC</u> inches	<u>4</u> inches	<u>- 20</u> feet	<u>300</u> feet

Was casing drive shoe used? ☒ Yes ☐ No

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☒ Yes ☐ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation 1/4 inches by 1/4 inches * Drill

Number	From	To
<u>50</u> perforations	<u>220</u> feet	<u>240</u> feet
<u>50</u> perforations	<u>190</u> feet	<u>200</u> feet
<u>50</u> perforations	<u>140</u> feet	<u>160</u> feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 32 Material used in seal: ☐ Cement grout

☒ Bentonite ☐ Puddling clay ☒ Cuttings

Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing

☒ Overbore to seal depth

Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent

Weld

☐ Cemented between strata

Describe access port _____

9. LITHOLOGIC LOG

Bore Dism.	Depth		Material	Water	
	From	To		Yes	No
<u>8</u>	<u>0</u>	<u>3</u>	<u>Topsoil</u>		<u>Y</u>
	<u>3</u>	<u>28</u>	<u>Decomposed Granite</u>		<u>Y</u>
	<u>28</u>	<u>32</u>	<u>Granite</u>		<u>Y</u>
<u>6</u>	<u>32</u>	<u>300</u>	<u>Granite (Soft Areas)</u>	<u>Y</u>	

Water at 285

SCANNED
OCT 18 2017

RECEIVED
SEP 13 1985
Department of Water Resources
MICROFILMED