Form 238-7
3/95

SEP 30 1996
IDWR

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 096963

Use Typewriter or Ballpoint Pen

Office Use Only
Inspected by_____
Twp____Rge____ Sec____
____1/4____1/4____1/4
Lat: : : Long: : :

1. DRILLING PERMIT NO. 95-96-N-108-000
Other IDWR No. STATE

2. OWNER **Well Number:** 442
Name GRENNAY, JOHN
Address N 4911 REBECCA ST
City SPOKANE State WA Zip 99207

3. LOCATION OF WELL by legal description
sketch map location must agree with written location

N / W / E / S — X

Twp. 48 ☒ North or ☐ South
Rge. 04 ☐ East or ☒ West
Sec. 30 ____ 1/4 SE 1/4 SE 1/4
Gov't Lot ____ County KOOTENAI
Lat: : : Long: : :
Address of Well Site WINDY BAY
City ____
(Give at least name of road + Distance to Road or Landmark)
Lt. ____ Blk. ____ Sub. Name ____

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

5. TYPE OF WORK check all that apply (Replacement, etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other ____

6. DRILL METHOD
☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	20	0 SACK	DRY

Was drive shoe used? ☐ Y ☐ N Shoe Depth(s)____
Was drive shoe seal tested? ☐ Y ☐ N How?____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	118	.250	STEEL	☒	☐	☒	☐
4	-5	135	200	PVC	☐	☒	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☒ Perforations Method SKILLSAW
☐ Screens Screen Type ____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
115	135	1/8	80	0	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
80 ft. below ground Artesian pressure____ lb.
Depth flow encountered____ ft. Describe access port or control devices: ____

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
9			

Water Temp. ____ Bottom Hole Temp ____
Water Quality test or comments: ____
____ Depth first Water encountered ____

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water Y	Water N
8	0	2	TOPSOIL	☐	☒
8	2	20	Basalt Broken W/Clay	☒	☐
6	20	70	Basalt Broken W/Clay	☒	☐
6	70	85	Basalt Gravels Large Some Clay	☒	☐
6	85	95	Clay Brown	☐	☒
6	95	118	Basalt Broken	☐	☒
6	118	135	Basalt Fractured	☒	☐

Completed Depth 135' (Measurable)
Date: Started 08/19/96 Completed 08/20/96

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H20 WellService, Inc. Firm No. 448
Firm Official [signature] Date 9-4-96
and
Supervisor or Operator [signature] Date 9-4-96
(Sign Once if Firm Offical and Operator)

SESE 30 48N 4W

SCANNED
DEC 14 2017