

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	



1. WELL TAG NO. D0051950

Drilling Permit No: 847003
Other IDWR No.

2. OWNER

Name PARODY, FRANCES

Well Number:

1314

Address 17951 S. RACCOON COURT

City COEUR D' ALENE State ID Zip 83814

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N			
W			
S			

Twp. 48N ☒ North or ☐ South
Rge. 04W ☐ East or ☒ West
Sec. 17 ☐ 1/4 NW ☐ 1/4 NE ☐ 1/4
Gov't Lot _____ County KOOTENAI
Latitude: N47:30:400 Longitude: W116:53:411

Address of Well Site SAME

City COEUR D' ALENE

(Give at least name of road + Distance to Road or Landmark)

Lt. 3 Blk. _____ Sub. Name Rockford Bay Sum

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT Sacks or Pounds	METHOD
Material	From	To		
BENTONITE	+1	39	400 LBS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 39

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	39	250	STEEL	☒	☐	☒	☐
4	-5	260	.200	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILL SAW

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
205	245	1/8 X 6	70	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

56 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 160 ft. Describe access port or control devices:

48N 4W 17

11. WELL TESTS:

☐ Pump	☐ Bailer	☒ Air	☐ Flowing Artesian
Yield gal./min.	Drawdown	Pumping Level	Time
3			1HR

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: GOOD

Depth first Water encountered 160

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water
10	0	2	Top Soil	☐ Y ☒ N
10	2	12	Clay, gravel brown med.	☐ Y ☒ N
10	12	18	Clay basalt, brown broken	☐ Y ☒ N
10	18	25	Clay basalt, brown broken	☐ Y ☒ N
10	25	39	Soft Brown Basalt	☐ Y ☒ N
6	39	92	Soft Brown Basalt	☐ Y ☒ N
6	92	148	Black Med. Basalt	☐ Y ☒ N
6	148	160	Black/Purple Med. Basalt	☐ Y ☒ N
6	160	182	Black Fract. Basalt 3 ppm	☒ Y ☐ N
6	182	270	Black Med. Basalt	☐ Y ☒ N
6	270	325	Brown Clay	☐ Y ☒ N
6	325	380	Gray Clay	☐ Y ☒ N

SCANNED
DEC 22 2017

RECEIVED
June 29 2007
DWR/North

Completed Depth 260 (Measurable)
Date: Started 6/11/2007 Completed 6/13/2007

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2B Well Service, Inc. Firm No. 448

Firm Official _____ Date 6-20-07

and Supervisor or Operator Bob Kern Date 6/15/07

BOB KERN (Sign Once if Firm Official and Operator)