

USE TYPEWRITER OR
BALL POINT PEN

State of Idaho
Department of Water Administration

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation Engineer
within 30 days after completion or abandonment of the well.

RECEIVED

1. WELL OWNER

Name Jim DOLLIVER
Address C.D.A. 22a
Owner's Permit No. 95-71-N-6

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 8 inches Total depth 300 feet
Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>1.250</u> inches	<u>6</u> inches	<u>+1</u> feet	<u>185</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☒ Yes ☐ No
How perforated? ☐ Factory ☐ Knife ☒ Torch
Size of perforation 1.250 inches by 12 inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No


Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feet

Surface seal? ☒ Yes ☐ No To what depth 22 feet
Material used in seal ☐ Cement grout ☒ Pudding clay

6. LOCATION OF WELL

Sketch map location must agree with written location.



LOT 1

95

County HOOTENIA

SW 1/4 NW 1/4 Sec. 10, T. 48 N., R. 4 E

7. WATER LEVEL

Department of Water Administration

Static water level 200 feet below land surface

Flowing? ☐ Yes ☐ No G.P.M. flow _____

Temperature 60° F. Quality Good

Artesian closed-in pressure _____ p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
<u>1</u>	<u>—</u>	<u>2</u>
_____	_____	_____
_____	_____	_____

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
8	0	10	CLAY + ROCK		X
	10	12	SAND		X
	12	60	CLAY + BOULDERS		X
	60	70	MICA + SAND		X
	70	90	CLAY + BOULDERS		X
	90	185	GREEN SHALE		X
	185	270	HARD BASALT		X
	270	300	SOFT BASALT	X	

SCANNED
JAN 09 2018

00705.1

10.

Work started 23 aug 71 finished 30 aug 71

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is true to the best of my knowledge.

Agnes Drilling & Development Inc 163
Driller's or Firm's Name Number

101 Ogino, Idaho 835-744
Address

Richard Kendrick 6-10-92
Signed By Date

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE, BLUE, AND PINK COPIES TO THE DEPARTMENT