

REPORT OF WELL DRILLER
State of Idaho



APR 4 1966
10:35 A.M.
Department of Reclamation

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:

Name E. A. BURGESS

Address LA CROSSE WASH

CONKLIN PARK I DAHO 94-66-N-4

Owner's Permit No. _____

NATURE OF WORK (check): Replacement well ☐

New well ☒ Deepened ☐ Abandoned ☐

Water is to be used for: summer home lake

METHOD OF CONSTRUCTION: Rotary ☐ Cable ☒

Dug ☐ Other _____

(explain)

CASING SCHEDULE: Threaded _____ Welded _____

6 "Diam. from Top ft. to 44 ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

Thickness of casing: .025 Material: _____

Steel ☒ concrete ☐ wood ☐ other ☐

(explain)

PERFORATED? Yes ☐ No ☒ Type of perforator used: _____

Size of perforations: _____ " by _____ "

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

WAS SCREEN INSTALLED? Yes ☐ No ☒

Manufacturer's name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION: Well gravel packed? Yes ☐

No. ☒ size of gravel _____ Gravel

placed from _____ ft. to _____ ft. Surface seal

provided? Yes ☐ No ☐ To what depth?

_____ ft. Material used in seal: _____

Did any strata contain unusable water? Yes ☐

No. ☒ Type of water: _____

Depth of strata _____ ft. Method of sealing

strata off: _____

Surface casing used? Yes ☐ No. ☐

Cemented in place? Yes ☐ No ☐

Locate well in section

LOCATION OF WELL: County KOOTENAI

* * * Sec. 20 T. 47 N. R. 3 W.

Lake side addition
conklin Park lot 10

Use other side for additional remarks

Size of drilled hole: 6 1/2 Total
depth of well: 56 ft Standing water
level below ground: 42 Temp.
Fahr. 46 ° Test delivery: 20 gpm
or _____ cfs Pump? ☐ Bail ☒

Size of pump and motor used to make test: _____

Length of time of test: _____ Hrs. Min.

Drawdown: 2 ft. Artesian pressure: ft.

above land surface Give flow _____ cfs

or _____ gpm. Shutoff pressure: _____

Controlled by: Valve ☐ Cap ☐ Plug ☐

No control ☐ Does well leak around casing?

Yes ☐ No ☒

DEPTH FROM TO	MATERIAL	WATER YES OR NO
0 10	broken basalt and clay	NO
10 40	clay	NO
40 56	hard basalt	YES

FEEET FEET

0 10 broken basalt and clay NO

10 40 clay NO

40 56 hard basalt YES

SCANNED
JAN 22 2018

Work started: MARCH 11 - 1966

Work finished: MARCH 18 1966

Well Driller's Statement: This well was drilled under my supervision and this report is true to the best of my knowledge.

Name: Frederick Bros Well Drilling

Address: Blummen Idaho

Signed by: Wilmet Frederick

License No. 279 Date: 3-31-66