

RECEIVED

Form 238-7 JUL 05 2001
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 _____ 1/4 _____ 1/4 _____
Lat: _____ Long: _____

1. WELL TAG NO. D 0017348

DRILLING PERMIT NO. _____
Other IDWR No. 769691

2. OWNER: Wes Evans
Name _____
Address 16411 S. Francis Faire
City Worley State ID Zip 83876

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N
W
E
S
Twp. 48 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 8 1/4 NE 1/4 NE 1/4
Gov't Lot _____ County Kootenai
Lat: _____ Long: _____
Address of Well Site 16411 S. Francis
Faire City Worley
(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK	AMOUNT	METHOD
Material	From To Sacks or Pounds	
Bentonite	0 18 300#	overbore

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) ring bit

Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	142	250	Steel	☒	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations Method _____
Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

78 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
50 gpm			

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: _____

Depth first Water Encounter 126

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	3	Clay, brown		X
	3	16	Clay, dark brown		X
	16	18	Clay, dark brown, wet		X
8	18	26	Clay, grey brown		X
	26	39	Basalt, soft, vesicular		X
	39	61	Basalt, medium		X
	61	66	Clay, grey		X
	66	85	Clay, brown		X
	85	123	Clay, dark brown		X
	123	131	Basalt, soft 10 gpm	X	
	131	143	Basalt, vesicular 40 gpm	X	

RECEIVED

SEP 14 2001

Department of Water Resources

SCANNED

FEB 13 2018

Completed Depth 142' (Measurable)
Date: Started 06/27/01 Completed 06/28/01

13. DRILLER'S CERTIFICATION

We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name McCarty Drilling & Pump Inc. No. 586

Firm Official _____ Date 6-30-01

and _____

Driller or Operator _____ Date _____

(Sign once if Firm Official & Operator)

48N 5W 8

FORWARD WHITE COPY TO WATER RESOURCES