Form 238-7
1/94

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

RECEIVED APR 21 1994 Department of Water Resources

Renumbered by Region 092282

1. DRILLING PERMIT NO. 95-94 N 50 000

Other IDWR No. 95-08860

2. OWNER:

Name POE ASPHALT

Address PO BOX 449

City LEWISTON State ID Zip 83501

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

Twp. 51 North ☒ or South ☐

Rge. 05 East ☐ or West ☒

Sec. ~~31~~ 30 SW 1/4 SW 1/4 1/4

10 acres 160 acres

Gov't Lot ____ County KOOTENAI

Address of Well Site (STATELINE)-BECK RD.

City ____

(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name ____

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other Industrial

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	40	100 GALS	SLURRY POURED

Was drive shoe used? Y ☐ N ☐

Was drive shoe seal tested? Y ☐ N ☐ How? ____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+3	178	250	STEEL	☒	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS

☐ Perforations Method ____

☒ Screens Screen Type STAINLESS STEEL

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
178	188	100	2-5'	8"		☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

124' ft. below ground Artesian pressure ____ lb.

Depth flow encountered ____ ft. Describe access port or control devices: ____

SWSW 30 51N 5W

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
300+			

Water Temp. ____ Bottom hole temp. ____

Water Quality test or comments: ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
10	0	48	SAND & GRAVEL W/COBBLE W/ LIGHT BROWN SOILS		
10	48	72	SAND & GRAVEL COARSE CLEAN		
10	72	115	SAND & GRAVEL MEDIUM		
10	115	131	SAND & GRAVEL FINE W/LIGHT BROWN SOILS SEEMS		
10	131	188	GRAVEL COARSE CLEAN SOME FINES 3/4 MINIS MATERIALS	300+	

SCANNED FEB 28 2018

RECEIVED APR 15 1994 NORTHERN REGION IDWR

FEB 09 1995

Completed Depth ____ (Measurable)

Date: Started 03/21/94 Completed 03/24/94

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H20 WELL SERVICE INC Firm No. #448

Firm Official [signature] Date 4-8-94

and

Supervisor or Operator [signature] Date 4-5-94

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES