

WELL DRILLER'S REPORT 97224

Use Typewriter or Ballpoint Pen

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long
:	:	:	:

1. DRILLING PERMIT NO. 96-96-N-034-000

Other IDWR No. _____

2. OWNER

Name HOLECEK, LARRY


Well Number: 368

Address E 10533 PARKS RD

City ATHOL State ID Zip 83801

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 53 North or South

Rge. 03 East or West

Sec. 24 1/4 SW 1/4 NW 1/4

Gov't Lot _____ County KOOTENAI

Lat: _____ Long: _____

Address of Well Site _____

City _____

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Backs or Pounds	
BENTONITE	0	30+	2 BAGS	verbores/ 100 gals

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 174

Was drive shoe seal tested? ☒ Y ☐ N How? Drove into Rock

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	174	.250	STEEL	☒	☐	☐	☐
4	-164	304	.160	PS/PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
264	304	1/8X4"	140	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

215 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10 TO 12 GPM			

Water Temp. _____ Bottom Hole Temp _____

Water Quality test or comments: _____

Depth first Water encountered _____

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	Y	N
8	0	3	Topsoil		☐	☒
8	3	26	Sand & Gravel 1.5 Minis		☐	☒
8	26	74	Sand & Gravel W/Clay & Cobble 3/4		☐	☒
8	74	110	Sand & Gravel 3/4 Minis		☐	☒
8	110	113	Boulder		☐	☒
8	113	174	Cemented Gravel w/Clay		☐	☒
6	174	183	Granite Salt & Pepper Hard		☐	☒
6	183	218	Granite Salt & Pepper W/Rose Medium		☐	☒
6	218	265	Granite Salt & Pepper Hard		☐	☒
6	265	273	Granite Fractured Salt & Pepper Green		☐	☒
6	273	304	Granite Salt & Pepper Medium		☐	☒
	0	0	Granite/Shale		☐	☐

RECEIVED

APR 17 1996

IDAHO DEPARTMENT OF WATER RESOURCES
IDWR

Completed Depth 304' (Measurable)

Date: Started 03/22/96 Completed 03/25/96

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official John Whelan Date 4-11-96

and Supervisor or Operator J. E. Hoff Date 4-11-96

(Sign Once If Firm Official and Operator)

SCANNED
SEP 12 2011