

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.USE TYPEWRITER OR
RECEIVED
PH-9
JUN 27 1988

1. WELL OWNER

Name Terry Wall
Address P.O. Box 73
Maceo, KY 42355
Owner's Permit No. 95-88-N-05

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED

☒ Rotary ☒ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Auger ☐ Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other PVC
Thickness _____ Diameter _____ From _____ To _____
0.250 inches 6 inches + 1 feet -78 feet
PVC inches 4 inches _____ feet 652 feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feetWas casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☒ Yes ☐ No
Perforated? ☒ Yes ☐ No
How perforated? ☐ Factory ☒ Knife ☐ Torch
Size of perforation 1/2 inches by 4 inches
Number _____ From _____ To _____
80' perforations 232 feet 312 feet
80' perforations 392 feet 472 feet
80' perforations 572 feet 652 feetWell screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____
Placed from _____ feet to _____ feet
Surface seal depth 78 Material used in seal: ☐ Cement grout
☒ Bentonite ☐ Pudding clay ☐ _____
Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing
☐ Overbore to seal depth
Method of joining casing: ☐ Threaded ☒ Welded ☒ Solvent
Weld
☐ Cemented between strata

Describe access port _____

6. LOCATION OF WELL

Sketch map location must agree with written location.

N
W E
S
County Kootenai
Subdivision Name _____
Lot No. _____ Block No. _____
SW 1/4 Sec. 15, T. 50 N, R. 3 E

7. WATER LEVEL

Static water level 200 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature _____ °F. Quality _____
Describe artesian or temperature zones below.

8. WELL TEST DATA

☐ Pump ☐ Bailor ☒ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>6</u>	<u>652</u>	<u>6</u>

9. LITHOLOGIC LOG

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
8	0	78			X
6	78	652			
	0	2	top soil		X
	2	60	Brown shale		X
	60	70	Soft Blue Rock		X
	70	130	hard Brown shale		X
	130	132	Blue shale		X
	132	135	hard Brown shale		X
	135	140	Blue shale		X
	140	152	Brown shale		X
	152	202	Blue shale		X
	202	235	Brown shale		X
	235	350	Blue shale	X	
	350	652	hard grey & Blue shale	X	

First water 250 2 gpm
Second water 340 2 gpm
Third water 480 2 gpm**RECEIVED**

JUN 17 1988

Department of Water Resources
Northern District Office
013574

10.

Work started 6-9-88 finished 6-15-88

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
complied with at the time the rig was removed.Firm Name H2O well Service Firm No. 448Address 582 W. Handman Date _____
Longview Lake IdahoSigned by (Firm Official) John Wheelerand
(Operator) Wayne Miller