USE TYPEWRITER OR BALL POINT PEN

te of Idaho
Department of Water Resources

ENT'D

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name Mildred Imhart

Address 512 ½ Main

Owner's Permit No. Kellogg Ida.

2. NATURE OF WORK 95-78-N-9

☑ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☑ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☑ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 22 feet

Casing schedule: ☐ Steel ☐ Concrete

Thickness	Diameter	From	To
.250 inches	6 inches	+1 feet	21 feet
inches	inches	feet	feet
inches	inches	feet	feet
inches	inches	feet	feet
inches	inches	feet	feet

Was casing drive shoe used? ☑ Yes ☐ No

Was a packer or seal used? ☐ Yes ☑ No

Perforated? ☐ Yes ☑ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation ____ inches by ____ inches

Number	From	To
perforations	feet	feet
perforations	feet	feet
perforations	feet	feet

Well screen installed? ☐ Yes ☑ No

Manufacturer's name

Type Model No.

Diameter ___ Slot size ___ Set from ___ feet to ___ feet

Diameter ___ Slot size ___ Set from ___ feet to ___ feet

Gravel packed? ☐ Yes ☑ No Size of gravel

Placed from ___ feet to ___ feet

Surface seal depth 20 Material used in seal ☐ Cement grout ☑ Puddling clay ☑ Well cuttings

Sealing procedure used ☐ Slurry pit ☑ Temporary surface casing ☑ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name Finney Tract

Lot No. 5 & 6 Block No. 3

County Kootenai

Lot 3 ¼ ¼ Sec. 4, T. 49 N/S, R. 3 E/W (B.M.)

7. WATER LEVEL

Static water level 100 feet below land surface

Flowing? ☐ Yes ☐ No G.P.M. flow

Temperature ° F. Quality

Artesian closed-in pressure p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☑ Other

Discharge G.P.M.	Draw Down	Hours Pumped
10		

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
6	0	5	Surface soil		✓
6	5	300	granite brown hard	✓	

RECEIVED
MAR 6 1979
Department of Water Resources
Northern District Office

10. Work started 6-14-78 finished 6-15-78

11. DRILLERS CERTIFICATION

Firm Name Aqua Drilling Inc. Firm No.

Address P.O. Box 659 Date 6-15-78

Signed by (Firm Official) Edward Lewis

and

(Operator) Joel Lewis

95-14456

SCANNED

OCT 20 2009

USE ADDITIONAL SHEETS IF NECESSARY FORWARD THE WHITE COPY TO THE DEPARTMENT