



95-91-N-125-501
Permit No. 95-91-N-125

RECEIVED
OCT 01 1991
NORTHERN REGION
IDWR

HYDRO-FRACTURING LOG

1. OWNER: Name Saint Dominics School
Address: 5450 W. Riverview Drive, Post Falls, ID 83854

Total depth 324 Diameter 6"

2. LOCATION OF WELL: County Kootenai
NW 1/4 NW 1/4 Sec. 18 T 50N N, R 5 WM

3. TYPE OF WORK: Hydro-fracturing

4. WELL TESTS:

Yield:	gal./min. with	ft. drawdown after	Hrs.
Pre-frac:	1.05		
Post-frac:	4.48	214	2 1/4

5. HYDRO-FRACTURING LOG

Hydro-fractured at depths of:	
324 - 294 ft	
294 - 231 ft	
231 - 168 ft	
168 - 105 ft	
105 - 42 ft	

6. HYDRO-FRACTURER'S STATEMENT:
This well was hydro-fractured under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Northwest Hydro-fracturing
Address W. 13712 Lincoln Road, Spokane, WA 99204
Signed [Signature]
Date September 26, 1991

NW NW 18 50N 5W

Identify

Identify From: Taxlots

Taxlots

DOMINICAN SISTERS OF IDAHO INC

Location: 2,273,250.409 1,836,162.059 Meters

Field	Value
ID	9309403
UPDATED	3/23/2018
PIN	50N05W183150
OWNER	DOMINICAN SISTERS OF IDAHO INC
ADDRESS1	20274 W RIVERVIEW DR
ADDRESS2	<null>
CITY	POST FALLS
STATE	ID
ZIPCODE	83854
P_ADDRESS	20273 W RIVERVIEW DR
P_ZIPCODE	<null>
SUB_NAME	
LEGAL1	TAX#24626 1850N05W
LEGAL2	<null>
LEGAL3	<null>
LEGAL4	<null>
LEGAL5	<null>
LEGAL6	<null>
ACRES	0.6
COUNTY	Kootenai
SOURCE	<null>
YEAR_BUILT	1991

Identified 1 feature

Identify

Table Of Contents