RECEIVED
MAY 19 1995
NORTHERN REGION
IDWR

Form 238-7
R94

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

1. ~~DRILLING PERMIT NO.~~ 95 - 95 - N - 0064 - 000
Other IDWR No.

2. OWNER:
Name TOUTANT, MIKE
Address 9100 W. RIDGELINE LANE
City COEUR D'ALENE State ID Zip 83814

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 50 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 24, NE 1/4 (10 acres) SW 1/4 (40 acres) ____ 1/4 (160 acres)
Gov't Lot 11 County KOOTENAI

Address of Well Site RICH LINE ESTATES OFF GREEN FERRY City
(Give at least name of road + Distance to Road or Landmark)

Lt. 11 Blk. Sub. Name

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	20	5 SACKS	DRY GRANULE
OVER BORE				

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s)
Was drive shoe seal tested? Y ☐ N ☒ How? DROVE INTO ROCK

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+4	21	.250	STEEL	☒	☐	☒	☐
4	+4	560	200	PSI PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS
☒ Perforations Method SKILL SAW
☒ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
500	520	1/8x4	70	4	PVC	☐	☒
540	560	1/8x4	70	4	PVC	☐	☒
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
320 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices:

Govt Lt SW 24 50N 5W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10		560	1 HR

Water Temp. Bottom hole temp.
Water Quality test or comments:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	4	SANDY LOAM TOPSOIL		X
8	4	21	GRANITE DECOMP BROWN		X
8	21	165	GRANITE BLACK & COPPER. WHITE		X
8	165	169	GRANITE WHITE & GREEN SOFT	X	
8	165	169	DECOMPOSED	X	
8	169	350	GRANITE BLACK & WHITE MED		X
8	350	480	GRANITE WHITE & BLACK ROSE		X
8	480	545	GRANITE BLACK & WHITE		X
8	545	552	GRANITE WHITE & GREEN W/WATER	X	
8	545	552	APPROX 10 GPM	X	
8	552	560	GRANITE BLACK & WHITE MED		X
			Liner to top of hole		

RECEIVED
MAY 19 1995
NORTHERN REGION
IDWR

Completed Depth 560 (Measurable)
Date: Started 05/11/95 Completed 05/12/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WELL SERVICE, INC. Firm No. 448
Firm Official JOHN H. WHEELER SR. Date 05/18/95
and
Supervisor or Operator LOUIS HANNER Date 05/18/95
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES