

RECEIVED

NOV 06 2001

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

IDWR/North

1. WELL TAG NO. D0017970

DRILLING PERMIT N

Other IDWR No

2. OWNER:

Name Carol Flory

Address 9429 S Gozzer RD

City Coeur d'Alene

State ID

Zip 83814

3. LOCATION OF WELL by legal description:

N		Twp 49N North ☒ or South	
W		Rge 03W East or West ☒	
E		Sec 17 1/4 NW 1/4 NW 1/4	
S		10 Ac 40 Ac 160 Ac	
Gov't Lot		County Kootenai	
Lat		Long	

Address of Well Site: (see next line)

S Burma Rd and S Gozzer Rd first drive on left

City Harrison

Lot Blk Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	100	14 sacks	pour in

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 180'Drive Shoe Seal Tested? ☒ Y ☐ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrd
6	2	180	0.250	Steel	☒	☒	☒	☒
4	160	380	0.165	PVC	☒	☒	☒	☒

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

Perforations? Method
☒ Screens? Screen Type PVC

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
340	380	.20	2	4	PVC	☒	☒

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

110 ft. below ground. Artesian pressure lb.

Depth flow encountered 260,325,365 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS:

Pump	Bailer	☒ Air	Flowing Artesian
Yield gal./min.	Drawdown	Pump Level	Time
18	100%	379	1 hr.

Water Temp. cold

Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 260
clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
8	0	14	Clay - brown	Y	N
8	14	40	Basalt - black - hard	☒	☒
8	40	48	Basalt & clay - soft - brown	☒	☒
8	48	62	Clay - tan/beige	☒	☒
8	62	170	Clay - brown/orange	☒	☒
8	170	180	Shale - yellow/brown - medium	☒	☒
6	180	195	Shale - yellow/brown - medium	☒	☒
6	198	225	Granite - blue/gray - soft	☒	☒
6	225	230	Granite - brown/yellow - soft	☒	☒
6	220	245	Granite - gray - medium	☒	☒
6	245	250	Granite - brown/yellow - soft	☒	☒
6	250	310	Granite - blue/gray - medium -2 gpm @265	☒	☒
6	310	325	Granite - blue/gray - soft - 3 gpm @325	☒	☒
6	325	340	Granite - gray - medium - 2 gpm @ 337	☒	☒
6	340	380	Granite - blue/gray - soft -11 gpm @365	☒	☒

RECEIVED

MAR - 1 2002

Idaho Department of Water Resources

SCANNED

SEP 14 2018

Completed Depth 380 (Measurable)
Date: Started 10/30/01 Completed 11/2/01

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official *Jason C. Beckham* Date 11/5/01
and
Supervisor or Operator Jason C. Beckham Date 11/5/01

FORWARD WHITE COPY TO WATER RESOURCES

49N 3W 17