


STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTUSE TYPEWRITER OR
BALLPOINT PENState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER Name <u>Metropolitan Mortgage & Securities</u> Address <u>W. 929 Sprague Ave., Spokane, WA 99204</u> <u>96-08470</u> Owner's Permit No. <u>96-86-N-120</u>	7. WATER LEVEL Static water level <u>410</u> feet below land surface. Flowing? ☐ Yes ☒ No G.P.M. flow <u>20</u> Artesian closed-in pressure _____ p.s.i. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature _____ °F. Quality _____
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Abandoned (describe method of abandoning) _____	8. WELL TEST DATA ☐ Pump ☐ Bailer ☒ Air ☐ Other _____ Discharge G.P.M. <u>20</u> Pumping Level _____ Hours Pumped _____ RECEIVED OCT 27 1986
3. PROPOSED USE ☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other _____ (specify type) _____	9. LITHOLOGIC LOG Department of Water Resources Northern District Office Material Hole Diam. Depth From To Water Yes No 12" 0 3' Top soil X 8" 3' 30' Boulder, gravel and sand X 8" 30' 47' Gravel, silt and sand X 8" 47' 54' Gravel & sand X 8" 54' 65' Coarse gravel & cobbles X 8" 65' 162' Gravel & sand X 8" 162' 167' Medium sand X 8" 167' 226' Gravel, cobbles & sand X 8" 226' 241' Gravel, silt & sand X 8" 241' 309' Gravel & sand some silt X 8" 309' 314' Sand & some gravel (cemented) X 8" 314' 333' Gravel & sand & some silt (cemented) X 8" 333' 338' 6" Granite boulder very hard X 8" 338' 396' Gravel cobbles, & sand (cemented) X 6" 396' 418' Gravel silt & some sand (cemented) X 6" 418' 466' Gravel cobbles & sand & silt X 100931 RECEIVED OCT 17 1986 RECEIVED OCT 31 1986 Department of Water Resources Department of Water Resources
4. METHOD DRILLED ☒ Rotary ☒ Air ☐ Hydraulic ☐ Reverse rotary ☐ Cable ☐ Dug ☐ Other _____	
5. WELL CONSTRUCTION Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____ Thickness .250 Diameter 8" Inches + 1 feet 336 feet .250 inches 6 inches 1 feet 462-2' feet Inches inches feet feet Inches inches feet feet Was casing drive shoe used? ☒ Yes ☐ No Was a packer or seal used? ☐ Yes ☒ No Perforated? ☐ Yes ☒ No How perforated? ☐ Factory ☐ Knife ☐ Torch Size of perforation _____ inches by _____ inches Number _____ From _____ To _____ _____ perforations _____ feet _____ feet _____ perforations _____ feet _____ feet _____ perforations _____ feet _____ feet Well screen installed? ☐ Yes ☒ No Manufacturer's name _____ Type _____ Model No. _____ Diameter _____ Slot size _____ Set from _____ feet to _____ feet Diameter _____ Slot size _____ Set from _____ feet to _____ feet Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____ Placed from _____ feet to _____ feet Surface seal depth <u>30'</u> Material used in seal: ☐ Cement grout ☒ Puddling clay ☐ Well cuttings Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing ☒ Overbore to seal depth Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld ☐ Cemented between strata Describe access port _____	
6. LOCATION OF WELL Sketch map location must agree with written location.  Subdivision Name _____ Lot No. _____ Block No. _____ County <u>Kooteni</u> SW <u>11</u> SE <u>11</u> Sec. <u>11</u> , T. <u>53</u> N., R. <u>3</u> W.	10. Work started <u>8/20/86</u> finished <u>8/28/86</u>
11. DRILLERS CERTIFICATION I/We certify that all minimum well construction standards were compilled with at the time the rig was removed. Bartholomew Drilling, Inc. Firm Name _____ Firm No. <u>52</u> Address <u>N. 11525 Nine Mile Rd.</u> Date _____ <u>Nine Mile Falls, WA 99026</u> Signed by (Firm Official) <u>Bartholomew</u> and _____ (Operator) <u>Bartholomew</u>	