

USE TYPEWRITER OR
BALL POINT PEN



State of Idaho
Department of Reclamation

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation
within 30 days after completion or abandonment of the well

Location Corrected by IDWR To:

T39N R06W Sec. 25 NENENW

By: segbert 2012-04-17

1. WELL OWNER

Name RALPH JENNINGS
Address MOSCOW IDAHO
Owner's Permit No. 87-69-N-4

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 276 feet
Casing schedule: ☐ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>82</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet


Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feet

Surface seal? ☒ Yes ☐ No To what depth 81 feet
Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.



County LATAH
NW 1/4 NW 1/4 Sec. 25, T. 39 N, R. 6 W

7. WATER LEVEL

Static water level 40 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow 6
Temperature 54 ° F. Quality GOOD
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other AIR TEST

Discharge G.P.M.	Draw Down	Hours Pumped
<u>6</u>		

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
8"	0	50	CLAY		☒
8"	70	81'	DECOMPOSED GRANITE		
6"	81	252	GRAY WHITE DECOMPOSED GRANITE		
6"	252	276	PINKISH DECOMPOSED GRANITE		
			WATER BEARING		
			WELL ~~WAS~~ PRODUCED		
			1 GPM MIN - FROM		
			81' TO 252'		
			5 GPM IN ZONE		
			252' TO 276'		

10. Work started DEC 9 (69) finished DEC 12 (69)

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is true to the best of my knowledge.

Burns & Watt 58-103
Driller's or Firm's Name Number
2019 POWERS CLEWISTON
Address
G.R. Burns April 15 1970
Signed By Date