



RECEIVED

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

Department of Water Resources
Northern District Office

1. WELL OWNER

Name ROBERT NEWALLAddress MOSCOW IDAHOOwner's Permit No. 87-76-N-16

7. WATER LEVEL

Static water level 41 feet below land surfaceFlowing? ☐ Yes ☒ No G.P.M. flowTemperature 55 ° F. Quality GOOD

Artesian closed-in pressure _____ p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 305 feetCasing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>.250</u> inches	<u>8</u> inches	<u>2</u> feet	<u>32</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☐ Yes ☒ NoWas a packer or seal used? ☐ Yes ☒ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet


Gravel packed? ☐ Yes ☒ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 22' Material used in seal ☐ Cement grout☒ Pudding clay ☐ Well cuttingsSealing procedure used ☐ Slurry pit ☐ Temporary surface casing☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County LATAHNW 1/4 SW 1/4 Sec. 35, T. 41, N. 8, R. 5 E/W

8. WELL TEST DATA

AIR TEST, 6 GPM☐ Pump ☐ Bailer ☒ Other

Discharge G.P.M.	Draw Down	Hours Pumped
_____	_____	_____
_____	_____	_____
_____	_____	_____

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
<u>10</u>	<u>0</u>	<u>14</u>	<u>OVERBURDEN</u>		<u>X</u>
<u>10</u>	<u>14</u>	<u>34</u>	<u>DECOMPOSED GRANITE</u>		<u>X</u>
			<u>FIRM</u>		
<u>6</u>	<u>34</u>	<u>52</u>	<u>DECOMPOSED GRANITE</u>		<u>X</u>
			<u>SOFTER</u>		
<u>6</u>	<u>52</u>	<u>99</u>	<u>HARD ZONE GRANITE</u>	<u>X</u>	
			<u>1 1/2 GPM @ 99</u>		
<u>6</u>	<u>99</u>	<u>132</u>	<u>SOFTER ZONE</u>		<u>X</u>
			<u>GRANITE</u>		
<u>6</u>	<u>132</u>	<u>272</u>	<u>HARD ZONE GRANITE</u>		<u>X</u>
			<u>SEAM AT 272' 1/2</u>		
			<u>GPM</u>		
<u>6</u>	<u>272</u>	<u>305</u>	<u>HARD WHITE</u>		<u>X</u>
			<u>GRANITE</u>		

005309

10.

Work started JAN 31, 1976 finished FEB 3, 1976

11. DRILLERS CERTIFICATION

Firm Name BURNS & WITT Firm No. 58/103Address 2019 POWER LEWISTON Date 3/15/76Signed by (Firm Official) G. R. Burns

and

(Operator) _____