

Form 238-7
6/07IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D D00 56441

Drilling Permit No. 856717

Water right or injection well # _____

2. OWNER

Name BRIAN DULINAddress 2800 NORTH MOUNTAIN VIEW ROADCity MOSCOW State ID Zip 83843

3. WELL LOCATION:

Twp. 40 North ☒ or South ☐ Rge. 05 East ☐ or West ☒Sec. 33 1/4 NW 1/4 SE 1/4Gov't Lot -- County LATAHLat. 46 ° 45.49.020 (Deg. and Decimal minutes)Long. 116 ° 58.11.780 (Deg. and Decimal minutes)Address of Well Site 2800 N MOUNTAIN VIEW ROADCity MOSCOW

(Give at least name of road + Distance to Road or Landmark)

Lot. -- Blk. -- Sub. Name --

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well ☐ Replacement well ☐ Modify existing well☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
BENTONITE	0	143	900#	TOP POUR

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
"8"	+2	143	.250	STEEL	☒	☐	☐	☒
4.5	130	173	160	PVC	☐	☒	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 143

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method SAWManufactured screen ☐ Y ☒ N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
130	173	1/8X4	42	4.5	PVC	160

Length of Headpipe N/A Length of Tailpipe _____Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
N/A				

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 168 Static water level (ft) 140Water temp. (°F) 55 Bottom hole temp. (°F) _____Describe access port TOP OF CASING - CAP

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
	6	60	☐	☐	☒	☐

Water Quality test or comments: GOOD

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
12	0	143	SAND & CLAY		X
8	143	173	HARD BLACK BASALT	X	

RECEIVED

JUN 29 2009

IDWR / NORTH

Completed Depth (Measurable)

173

Date: Started 06/11/09Completed 06/15/09

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name TWO U DRILLING, LLCCo. No. 125*Principal Driller [Signature] Date 06/15/09*Driller BU [Signature] Date 06/15/09

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

40N OSW 33