

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

JAN - 8 2002

Office Use Only

Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 _____ 1/4 _____ 1/4 _____
Long: _____

1. WELL TAG NO. D 0012247

DRILLING PERMIT NO. 771465

Other IDWR No. _____

2. OWNER:

Name Ron Bishop


Address P.O. Box 66

City Pocatello

State ID Zip 83855

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 41 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 2 1/4 NW 1/4 NW 1/4
Gov't Lot _____ County Latah
Lat: _____ Long: _____

Address of Well Site Same
City Pocatello

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From To	Sacks or Pounds		
benbrite	0 38	300 lbs		dry

Was drive shoe used? ☒ N ☐ Shoe Depth(s) _____

Was drive shoe seal tested? ☐ Yes ☒ No How? _____

8. CASING/LINER:

Diameter	From To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+1 38	250	Steel	☒	☐	☒	☐
6	-10 150		PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations Method Sew

Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
130	150	1/8x8	36	6	PVC	☐	☒
60	80	1/8x8	36	6	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

32 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

41N 5W 2

11. WELL TEST PWF North

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal/min.	Drawdown	Pumping Level	Time
approx 20			30 min.

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: _____

Depth first Water Encounter 78

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	3	overburden		
10	3	18	soft basalt		
10	18	24	clay		
10	24	31	soft basalt		
10	31	38	basalt firm		
8	38	41	basalt firm		
8	41	43	soft basalt		
8	43	44	basalt firm		
8	44	52	soft basalt		
8	52	67	basalt firm		
8	67	73	soft basalt		
8	73	78	basalt firm		
8	78	80	soft basalt		
8	80	91	clay		
8	91	111	soft basalt		
8	111	141	basalt firm		
8	141	145	conglomerate		
8	145	150	clay		

Completed Depth 150 (Measurable)
Date: Started 10/5/01 Completed 10/18/01

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name WITT Well Drilling Firm No. 58

Firm Official Roger Witt Date 1/5/02

and _____

Driller or Operator _____ Date _____

(Sign once if Firm Official & Operator)