RECEIVED

MAY 25 1999

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 076414

Office Use Only
Inspected by _____
Twp ____ Rge ____ Sec ____
____ 1/4 ____ 1/4 ____ 1/4
Lat: : : Long: : :

IDWR/North

1. WELL TAG NO. D 10050

DRILLING PERMIT NO. 87-99-N-9

Other IDWR No. _____

2. OWNER:

Name David Howard

Address 522 N. Jefferson

City Moscow State Id Zip 83843

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

POSTED

Twp. 41 North ☑ or South ☐

Rge. 5 East ☐ or West ☑

Sec. 26 NE 1/4 SE 1/4 NW 1/4

Gov't Lot ____ County Latah

Lat: : : Long: : :

Address of Well Site 1331 Flannigan Crk. Rd. City Viola

(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name ____

4. USE:

☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

5. TYPE OF WORK check all that apply (Replacement etc.)

☑ New Well ☐ Modify ☐ Abandonment ☐ Other ____

6. DRILL METHOD

☑ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
bentonite	0	18	100 lbs	dry

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s) ____

Was drive shoe seal tested? ☐ Y ☑ N How? ____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+2	18	250	Steel	☑	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS

Perforations Method ____

Screens Screen Type ____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

40 ft. below ground Artesian pressure ____ lb.

Depth flow encountered ____ ft. Describe access port or control devices: ____

11. WELL TESTS:

☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
approx. 4		305	30 min.

Water Temp. ____ Bottom hole temp. ____

Water Quality test or comments: ____

Depth first Water Encounter 28

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
12	0	5	overburden		✓
12	5	12	soft granit		✓
12	12	18	granit firm		✓
8	18	314	granit, firm	✓	

Completed Depth 314 (Measurable)

Date: Started 5/18/99 Completed 5/20/99

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Witt Well Drilling Firm No. 58

Firm Official Roger Witt Date 5/23/99

and

Driller or Operator ____ Date ____

(Sign once if Firm Official & Operator)

41 N 5 W 26

FORWARD WHITE COPY TO WATER RESOURCES