

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp _____ Age _____ Sec _____
_____ 1/4 _____ 1/4 _____ 1/4
Lat : : : Long: : :

1. WELL TAG NO. D 0033385

DRILLING PERMIT NO. - - - -

Other IDWR No. _____

2. OWNER


21. OWNER
Name Tom Partington & Judy Tackett

Address 1237 Crumarine Loop Road

City Moscow State ID Zip 83843

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 40 North ☒ or South ☐
 Rge. 5 East ☐ or West ☒
 Sec. 36 NW 1/4 NE 1/4 _____ 1/4
 Gov't - Lot _____ County Latah _____
 Lat. : : Long. _____
 Address of Well Site 1237 Crumarine Loop
 Road _____ City Moscow
(Give at least name of road - distance to road or landmark)

Li.	Bk.	Sub.	Name
-----	-----	------	------

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite Granuals	0	18	4S	Overbored Poured

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 18

Was drive shoe seal tested? ☒ Y ☐ N How? Air Test

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+2	18	250	Steel	☒	☐	☐	☐
4 1/2	-15	345	200 psi	PVC	☐	☒	☒	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

X	Perforations	Method	Saw Cut
----------	---------------------	---------------	----------------

Screens	Screen Type
---------	-------------

From	To	Slot Size	Number	Diameter	Material	Casing	Linear
305	345	1/8x6	90	4 1/2	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

45 ft. below ground Artesian pressure lb.

Depth flow encountered 65 ft. Describe access port or control devices: Well Cap

11. WELL TESTS:

☐ Pump ☐ Baller ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
1/2 gal			1 hour

Water Temp. 52 Bottom hole temp. _____

Water Quality test or comments: **Cool & Clear**

Depth first Water Encounter 65

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

[illegible]

13. DRILLER'S CERTIFICATION

We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Stuivenga Vessey Drilling Firm No. 545

Firm Official Stephen H. Kiser Date 11-24-03

and
Driver or Operator P. J. Gorman Date 11-24-03

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES