

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 _____ 1/4 _____ 1/4 _____
Lat: _____ Long: _____
☒ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

1. WELL TAG NO. D0013361

DRILLING PERMIT NO. _____
Other IDWR No. 765124

RECEIVED

JUL 12 2000

2. OWNER:

Name Stanley B. Smith

Address 512 E.D. St.

City Moscow

State ID IDWR/North Zip 83843

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

Sketch map location must agree with written location.

Twp. 41 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 14 1/4 SW 1/4 SW 1/4
Gov't Lot _____ County Latah
Lat: _____ Long: _____
Address of Well Site 3.5 mi. SW of
City Pottlatch

Pottlatch
(Give at least name of road - Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK	AMOUNT	METHOD
Material	From To Sacks or Pounds	
Bentonite	0 29 350#	top poor

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) _____

Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-118	250	Steel	☐	☐	☒	☐
4 1/2"	-110	-350	160	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations _____ Method Soft
Screens _____ Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-310	-350	1/8x4	77	4 1/2"	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

100 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

Yield gal./min.	Drawdown	Pumping Level	Time
22	_____	_____	1.00

Water Temp. 58.0 Bottom hole temp. _____

Water Quality test or comments: Good

Depth first Water Encounter 300

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	2	Dirt		X
8"	2	13	Clay		X
8"	13	29	Clay - Sand		X
8"	29	120	Sft to Med. @ Bottom		X
6"	120	300	Med. Granite		X
	300	350	Hd. & Sft.	X	

Completed Depth 350 ft. (Measurable)
Date: Started 6/20/00 Completed 6/20/00

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name UHLENKOTT Drilling Firm No. 125

Firm Official _____ Date 7-10-00

and _____

Driller or Operator _____ Date 7-10-00

(Sign once if Firm Official & Operator)

41N 5W 14 FORWARD WHITE COPY TO WATER RESOURCES