

Form 238-7
6/02

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Well ID No.			
Inspected by			
Twp	Rge	Sec	
	1/4	1/4	1/4
Lat:	:	Long:	:

1. WELL TAG NO. D 00 28471
DRILLING PERMIT NO. 803393
Water Right or Injection Well No. _____

2. OWNER:

Name Mike Gillen
Address 1285 Hudson Rd.
City Kent State OHIO Zip 44240

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 40 North ☒ or South ☐
Rge. 6 East ☐ or West ☒
Sec. 13 1/4 NE 1/4 NE 1/4
Gov't Lot _____
County LATAH 160 acres

Lat: _____ Long: _____
Address of Well Site 1 mile South of 2
City U101A

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply

(Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
Bentonite	0	56	550#	Top four

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) _____

Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-5P	250	Steel	☒	☐	☒	☐
4.5"	-30	-350	160	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method SAW

Screen Type & Method of Installation _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
310	330	1/4x4	65	4.5	PVC	☐	☒

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

60 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

40N 6W 13

12. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
40			1.5

Water Temp. 56° Bottom hole temp. _____

Water Quality test or comments: Good Depth first Water Encounter 325'

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water
8	0	56	Clay	✓
6	56	60	hd / hd Granite	✓
6	60	190	Soft Brown Granite	✓
6	190	299	SALT Pepper Granite	✓
6	299	325	Hard White Granite	✓
6	325	350	Soft Green Granite	40

RECEIVED

JUN 17 2003

IDWR North

Completed Depth 350 (Measurable)

Date: Started 6-9-03 Completed 6-10-03

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name WILLENKOTT DRILLING Firm No. 125

Principal Driller [Signature] Date 6-13-03
and
Driller or Operator [Signature]

Operator I _____ Date _____

Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.

FORWARD WHITE COPY TO WATER RESOURCES