

RECEIVED

Form 238-7
11/97

SEP 13 2001

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

IDWR/North

1. WELL TAG NO. D 17195

DRILLING PERMIT NO.

Other IDWR No. 769305

2. OWNER:

Name Ron Collins

Address 1054 Browns Lane

City Pocatello State ID. Zip 83855



3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N		Twp. 42		North ☒ or South ☐	
E		Rge. 4		East ☐ or West ☒	
S		Sec. 5		1/4 NE 1/4 NE 1/4	
		Gov't Lot		County Latah	
		Lat:		Long:	
		Address of Well Site Same		City	

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT		METHOD
Material	From	To	Sacks or Pounds		
bentonite	0	66	500 lbs		dry

Was drive shoe used? ☒ N Shoe Depth(s) 66

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+1	66	250	Steel	☒	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

Perforations Method
Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

130 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

42 N 4 W 5

FORWARD WHITE COPY TO WATER RESOURCES

Office Use Only

Inspected by

Twp Rge Sec

1/4 1/4 1/4

Lat: Long:

☒ Air ☐ Flowing Artesian

11. WELL TESTS:

☐ Pump ☐ Bailor

Yield gal./min.	Drawdown	Pumping Level	Time
approx 1 1/2		350'	30 min.

Water Temp.

Bottom hole temp.

Water Quality test or comments:

Depth first Water Encounter 247

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	8	overburden		☒
8	8	66	argillite soft		
8	66	68	argillite firm		
8	68	79	soft		
8	79	83	firm		
8	83	87	soft		
8	87	91	firm		
8	91	93	soft		
8	93	119	firm		
8	119	149	fract.		
8	149	160	firm		
8	160	162	fract.		
8	162	209	firm		
8	209	217	soft		
8	217	339	firm		☒
8	339	354	hard		

RECEIVED

SEP 14 2001

Department of Water Resources

Completed Depth 354 (Measurable)

Date: Started 6/5/01 Completed 6/11/01

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name WIT Well Drilling Firm No. 58

Firm Official Roger WITT Date 7/25/01

and Roger WITT

Driller or Operator Date

(Sign once if Firm Official & Operator)

