

RECEIVED

Form 238-7
11/97 JGE

JAN 08 2001

IDAHO DEPARTMENT OF WATER RESOURCES

IDWR/North

WELL DRILLER'S REPORT

1. WELL TAG NO. DD0013898

DRILLING PERMIT NO.

Other IDWR No. 767549

2. OWNER:

Name I. W. MINDEN

Address 1081 QUARTZ ROAD

City HARVARD

State ID Zip 83834

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N		Twp. 41		North ☒ or South ☐	
W		Rge. 3		East ☐ or West ☒	
S		Sec. 2		1/4 NE 1/4 SE 1/4	
		Gov't Lot		10 acres 20 acres 160 acres	
		Lat.		Long.	

Address of Well Site SAME

City

(Give at least name of road + Distance to Road or Landmark)

Lt. Bk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK: check all that apply

☒ New Well ☐ Modify ☐ Abandonment ☐ Other (Replacement etc.)

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES:

Seal/Filter Pack			AMOUNT		METHOD
Material	From	To	Sacks or Pounds		
BENTONITE	0	56	17		DRY

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 56Was drive shoe seal tested? ☒ Y ☐ N How? 300 PSI

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	0	56	1/4	STEEL	☒	☐	☒	☐
6	10	220	160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS:

☒ Perforations ☐ Screens Method DRY Saw

Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
190	230	1/8	60	6	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

135 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices: WELL CAP

41N 3W 2

FORWARD WHITE COPY TO WATER RESOURCES

Office Use Only

Inspected by

Twp. Rge. Sec.

1/4 1/4 1/4

Lat. Long.

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
6		200	1 HR

Water Temp. 50

Bottom hole temp.

Water Quality test or comments:

Depth first Water Encounter 209

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia	From	To	Remarks: Lithology, Water Quality & Temperature	Water
14	0	1	SOIL	Y N
14	1	45	CLAY BROWN	
8	45	56	ARGELITE SOFT BROWN	
8	56	127	ARGELITE SOFT BROWN	
8	127	163	ARGELITE MEDIUM BROWN	
8	163	167	ARGELITE SOFT BROWN	
8	167	209	ARGELITE MEDIUM BROWN	
8	209	221	ARGELITE SOFT BROWN	X
8	221	230	ARGELITE BROWN MEDIUM	

Completed Depth 230

(Measurable)

Date: Started 11/22/2000

Completed 11/22/2000

13. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name MCPHERSON & WRIGHT DRILLING Co. No. 0376

Firm Official

and

Driller or Operator

Date 12/27/2000

Date 12/27/2000